

## DEARNG - Seven (7) Converted Firing Ranges Lead Dust Remediation

New Castle and Sussex Counties, DE

H-11159

### ADDENDUM 4.0

#### RFI #3

December 7, 2012

This document is associated with the Delaware Army National Guard Lead Dust Remediation Seven (7) Converted Firing Ranges Project, (Harvard Reference Number H-11159), and is considered incorporated into the Contract Documents.

4.1 The following questions were presented to Harvard via e-mail on 12/7/12. The answers are provided.

- 4.1.1 Is the concrete painted floor Lead based paint? Or is the floor paint at all lead containing?
- a) The paint on the floors has been determined to be non-lead based paint. There is minimal content of lead in the paint. Results are not provided.**
- 4.1.2 Will I be allowed to submit clarifications with my bid or will that result in my bid being rejected in an effort to be able to cap/limit number of cleans as there is no way of knowing if efforts will be overly excessive to reach clearance?
- b) Bids will only be accepted has proposed based on the specifications and corresponding addendums.**
- c) Clearance (200  $\mu\text{g}/\text{ft}^2$  on the 6 ranges; 40  $\mu\text{g}/\text{ft}^2$  on the 198<sup>th</sup> Regiment Building range) must be achieved with no cap on the number of cleans.**
- 4.1.3 Addendum 1, section 1.16 and 1.19 has included the removal of 2'X2' and 20"x20" roof top exhaust vent (key note 7 on drawings) in 2 locations, Scannell and Duncan. Should I also include in my bid to enclose the roof openings? Addendums and schematics did not address enclosure?
- d) Enclosure was addressed in sub items 1.16.3 and 1.19.1 that reference the provisions for roof repairs, which are detailed in item 1.25.**

END OF ADDENDUM 4.0

**Attachment 4.1**  
**Meeting Attendance Record**  
**DEARNG - Seven (7) Converted Firing Ranges**  
**Lead Dust Remediation**

**H-11159**

**VALIDATION OF RECEIPT**  
**ADDENDUM 4.0**

Provided below is a check list of the electronic distribution of information associated with the project indicated above.

<b>Description</b>	<b>Received</b>	<b>Printed</b>
Addendum 4.0 – 1 Page		
Attachment 4.1 - Validation Of Receipt – 1 Page		

Name: \_\_\_\_\_ Company: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

**COMPLETED FORMS MUST BE FAXED TO**  
**HARVARD ENVIRONMENTAL, INC.**  
**1-302-326-2335**