



Delaware
315 S. Chapel Street
Newark, DE 19711
Phone
302.738.7172
Fax
302.738.7175

Pennsylvania
Duane Morris Plaza
30 S. 17th Street
Suite 830
Philadelphia, PA 19103
Phone
267.804.7286
www.dedc-eng.com

STATE OF DELAWARE – DELAWARE ARMY NATIONAL GUARD (DEARNG)
BBTS HVAC UPGRADES PHASE 3
FMO-DEARNG # 27670
DEARNG CONTRACT # 2018-05
ADDENDUM #3

GENERAL STATEMENTS:

1. A question was asked during the pre-bid meeting about whether a tie-in to the local fire department would be needed upon carbon monoxide detection in building 136 or duct mounted smoke detection within building 163. **Answer: The contractor is responsible for the installation of CO and smoke detection equipment per the drawing set. All fire department tie-ins, if required, will be handled by DEARNG.**
2. The location and quantity of carbon monoxide detectors and horns/strobes for building 136 were revised per the attached dwg. M-101 Rev-1.

Summarized By: DEDC, LLC
Ryan Malin
Date: July 6, 2018