

*Michael R. Wigley, AIA, LEED®AP
W. Zachary Crouch, P.E.
Michael E. Wheelleton, AIA
Jason P. Loar, P.E.
Ring W. Lardner, P.E.*

**DAGSBORO READINESS CENTER
MISCELLANEOUS INTERIOR IMPROVEMENTS
DAGSBORO, DELAWARE
DBF #0999J011.L06 ❖ OMB/DFM #MC7601000103**

AUGUST 21, 2018

ADDENDUM NO. 2

The following items shall become a part of the contract documents. Contractor must acknowledge receipt of this addendum on the Bid Form. Failure to do so may subject the Bidder to disqualification.

- Item No. 1 Refer to Pre-Bid Meeting Minutes, Item 12: The contractor shall submit for permit to the Town of Dagsboro. However, Dagsboro will not charge a permit fee.
- Item No. 2 Clarification: The only location sprinkler heads may need to be adjusted will be in area 133, behind Physical Fitness 134 for the new ceiling.
- Item No. 3 The fire alarm vendor is B.F.P.E. International, (302) 527-2373.
- Item No. 4 Clarification: No new fire extinguishers need to be installed.
- Item No. 5 Clarification to SK-1: The hollow metal cased opening shall be 16 gauge steel knockdown frame with three (3) fasteners per jamb and two (2) fasteners at the head.
- Item No. 6 Clarification to Note 14 on Sheet A1: The ADA faucet shall be Delta, model 591TP1250 or equal. The undermount lavatories shall be Kohler, Caxton Oval or equal, complete with drain, clamping assembly and mixing valve.
- Item No. 7 Clarification to 01/A2: All lights shown are new.
- Item No. 8 Clarification to Alternate #3 on Sheet A4: No demolition or patching of the masonry walls are anticipated. This alternate is to remove and replace the plumbing fixtures and connect to existing piping.
- Item No. 9 Any wall patching will be covered under the unforeseen allowance.
- Item No. 10 The owner will move the gym equipment and furniture away from walls. Furniture will not be moved out of the offices. The contractor shall protect the furniture during painting and ceiling work.

END OF ADDENDUM