

*Michael R. Wigley, AIA, LEED®AP
W. Zachary Crouch, P.E.
Michael E. Wheedleton, AIA
Jason P. Loar, P.E.
Ring W. Lardner, P.E.*

**DAGSBORO READINESS CENTER
MISCELLANEOUS INTERIOR IMPROVEMENTS
DAGSBORO, DELAWARE
DBF #0999J011.L06 ❖ OMB/DFM #MC7601000103**

AUGUST 24, 2018

ADDENDUM NO. 3

The following items shall become a part of the contract documents. Contractor must acknowledge receipt of this addendum on the Bid Form. Failure to do so may subject the Bidder to disqualification.

- Item No. 1 Clarification Addendum No. 2, Item 10: The user/owner will be responsible to move the furniture out of the areas to receive new flooring.
- Item No. 2 Smoke detectors are not located in the ceiling tiles.
- Item No. 3 The 2 x 2 LED lights in the toilet/shower rooms shall be Lithonia, 2GTL-2-33L-EZ1-LP835 or equal. The fixtures marked as emergency lights shall have an EM-ballast.
- Item No. 4 The basis-of-design for the toilet flush valve is Sloan, Royal Flushometer, 111-1.28, or equal.
- Item No. 5 The basis-of-design for the urinal flush valve is Sloan, Royal Flushometer, 186 HEU, or equal. The urinal flush valve shall have a volume of .125 gpf.

END OF ADDENDUM