



Delaware
315 S. Chapel Street
Newark, DE 19711
Phone
302.738.7172
Fax
302.738.7175

Pennsylvania
Duane Morris Plaza
30 S. 17th Street
Suite 830
Philadelphia, PA 19103
Phone
267.804.7286
www.dedc-eng.com

STATE OF DELAWARE – DEALAWARE ARMY NATIONAL GUARD (DEARNG)
DAGSBORO READINESS CENTER – AIR HANDLER 6 REPLACEMENT
DEARNG CONTRACT # 2019-23
ADDENDUM #2

- A. The email address for DEARNG project manager Guy Gravino was incorrectly written in Addendum #1. Correct email is: gaetano.a.gravino4.civ@mail.mil
- B. Addendum #2: The following drawings are attached to this Addendum #2 and have been revised per their description below.
1. M-101: HP-1 condensate pump info, DOAS-1 shift downward and bollard quantity decreased, wall penetrations and CO2 sensor notes added, HP-6 and pad corrected sizes shown and storm drain located for coordination.
 2. M-200: Fire damper detail added, smoke/fire damper detail note added.
 3. M-502: HP-1 controls diagram notes revised.
 4. E-000: Toggle disconnect switch symbol and notes added.
 5. E-101: HP-1 condensate pump info added.
 6. E-200: HP-1 condensate pump circuit info added.

Summarized By: DEDC, LLC
Ryan Malin
Date: August 4, 2020