

Addendum #3

Date: June 10, 2019

Project: DEARNG Contract No. 2019-13
Bethany Beach Training Site Infrastructure Utilities Upgrades-Electrical

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

General

1. The Overcurrent Protective Device Coordination Study referenced in Specification Section 26 05 73 shall be included in Alternate No. 1 in lieu of being included in the Base Bid. See the revised Specification Sections included in this Addendum for further information.

Changes to Specifications:

1. Specification Section 00 41 13, Bid Form, has been revised to include Alternate No. 1. See attached Bid Form 00 41 13.
2. Specification Section 01 23 00, Alternates, has been revised to include Alternate No. 1. See attached Alternates 01 23 00.

END

BID FORM

To: Delaware Army National Guard
Biden National Guard/Reserve Center
One Vavala Way
New Castle, DE 19720

(\$_____)

INFRASTRUCTURE UPGRADES - ELECTRICAL
BETHANY BEACH TRAINING SITE
DEARNG CONTRACT NUMBER 2019-13; Addendum #3

BID FORM

ALLOWANCE #1: We have included an allowance equal to \$20,000 to cover the costs of concealed conditions which may be encountered during the course of work.

Acknowledged by: _____

UNIT PRICES

Unit prices conform to applicable project specification section. Refer to the specifications for a complete description of the following Unit Prices:

UNIT PRICE: None

DEARNG CONTRACT NUMBER 2019-13; Addendum #3

BID FORM

I/We acknowledge Addendums numbered _____ and the price(s) submitted include any cost/schedule impact they may have.

This bid shall remain valid and cannot be withdrawn for thirty (30) days from the date of opening of bids (60 days for School Districts and Department of Education), and the undersigned shall abide by the Bid Security forfeiture provisions. Bid Security is attached to this Bid.

The Owner shall have the right to reject any or all bids, and to waive any informality or irregularity in any bid received.

This bid is based upon work being accomplished by the Sub-Contractors named on the list attached to this bid.

Should I/We be awarded this contract, I/We pledge to achieve substantial completion of all the work within 180 calendar days of the Notice to Proceed.

The undersigned represents and warrants that he has complied and shall comply with all requirements of local, state, and national laws; that no legal requirement has been or shall be violated in making or accepting this bid, in awarding the contract to him or in the prosecution of the work required; that the bid is legal and firm; that he has not, directly or indirectly, entered into any agreement, participated in any collusion, or otherwise taken action in restraint of free competitive bidding.

Upon receipt of written notice of the acceptance of this Bid, the Bidder shall, within twenty (20) calendar days, execute the agreement in the required form and deliver the Contract Bonds, and Insurance Certificates, required by the Contract Documents.

I am / We are an Individual / a Partnership / a Corporation

By _____ Trading as _____
(Individual's / General Partner's / Corporate Name)

(State of Corporation)

Business Address: _____

Witness: _____ **By:** _____
(SEAL) (Authorized Signature)

(Title)
Date: _____

ATTACHMENTS

Sub-Contractor List
Non-Collusion Statement
Affidavit(s) of Employee Drug Testing Program
Bid Security
(Others as Required by Project Manuals)

INFRASTRUCTURE UPGRADES/REPLACEMENTS

BETHANY BEACH TRAINING SITE
DEARNG CONTRACT NUMBER 2019-13; Addendum #3

BID FORM

SUBCONTRACTOR LIST

In accordance with Title 29, Chapter 6962 (d)(10)b Delaware Code, the following sub-contractor listing must accompany the bid submittal. The name and address of the sub-contractor **must be listed for each category** where the bidder intends to use a sub-contractor to perform that category of work. In order to provide full disclosure and acceptance of the bid by the *Owner*, **it is required that bidders list themselves as being the sub-contractor for all categories where he/she is qualified and intends to perform such work.** This form must be filled out completely with no additions or deletions. **Note that all subcontractors listed below must have a signed Affidavit of Employee Drug Testing Program included with this bid.**

Subcontractor Category

Subcontractor
Subcontractors tax payer ID #
or Delaware Business license #

Address (City & State)

1. Electrical _____

BETHANY BEACH TRAINING SITE
DEARNG CONTRACT NUMBER 2019-13; Addendum #3

BID FORM
NON-COLLUSION
SUSPENSION/DEBARMENT DISCLOSURE
STATEMENT

This is to certify that the undersigned bidder has neither directly nor indirectly, entered into any agreement, participated in any collusion or otherwise taken any action in restraint of free competitive bidding in connection with this proposal submitted this date to the State of Delaware, Delaware Army National Guard.

AFFIRMATION: Within the past five years, has your firm, any affiliate, any predecessor company or entity, owner, Director, officer, partner or proprietor been the subject of a Federal, State, Local government suspension or debarment?

YES _____ NO _____ If yes, please explain (use separate page and include with Bid Form.)

All the terms and conditions of DEARNG *Contract Number 2018-07* have been thoroughly examined and are understood.

NAME OF BIDDER: _____

**AUTHORIZED REPRESENTATIVE
(TYPED):** _____

**AUTHORIZED REPRESENTATIVE
(SIGNATURE):** _____

TITLE: _____

ADDRESS OF BIDDER: _____

E-MAIL: _____

PHONE NUMBER: _____

Sworn to and Subscribed before me this _____ day of _____ 20____.

My Commission expires _____. NOTARY PUBLIC _____.

THIS PAGE MUST BE SIGNED AND NOTARIZED FOR YOUR BID TO BE CONSIDERED.

INFRASTRUCTURE UPGRADES - ELECTRICAL

BETHANY BEACH TRAINING SITE
DEARNG CONTRACT NUMBER 2019-13; Addendum #3

**AFFIDAVIT
OF
EMPLOYEE DRUG TESTING PROGRAM**

4104 Regulations for the Drug Testing of Contractor and Subcontractor Employees Working on Large Public Works Projects requires that Contractors and Subcontractors implement a program of mandatory drug testing for Employees who work on Large Public Works Contracts funded all or in part with public funds.

We hereby certify that we have in place or will implement during the entire term of the contract a Mandatory Drug Testing Program for our employees on the jobsite that complies with this regulation:

Contractor/Subcontractor Name: _____

Contractor/Subcontractor Address: _____

Authorized Representative (typed or printed): _____

Authorized Representative (signature): _____

Title: _____

Sworn to and Subscribed before me this _____ day of _____ 20____.

My Commission expires _____. NOTARY PUBLIC _____.

THIS PAGE MUST BE SIGNED AND NOTARIZED FOR YOUR BID TO BE CONSIDERED.

SECTION 01 23 00

ALTERNATES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Description of Alternates.

1.02 RELATED REQUIREMENTS

- A. Document 00 21 13 - Instructions to Bidders: Instructions for preparation of pricing for Alternates.

1.03 ACCEPTANCE OF ALTERNATES

- A. Alternates quoted on Bid Forms will be reviewed and accepted or rejected at Owner's option. Accepted Alternates will be identified in the Owner-Contractor Agreement.
- B. Coordinate related work and modify surrounding work to integrate the Work of each Alternate.

1.04 SCHEDULE OF ALTERNATES

- A. Alternate #1 - Contractor shall perform short circuit analysis and coordination study of existing installation and new installation of equipment and wiring in accordance with Specification Section 26 05 73. This study will indicate available short circuit current at equipment and coordination of breakers to minimize hazard to personnel and equipment. As a part of the study the Contractor shall field verify installation of all existing equipment and wiring as shown on single line diagram and provide PPE labels at all equipment.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION