

Brandywine School District

11-28-16

TO: ALL OFFERORS

FROM: Carol Riddle
Construction Contract Coordinator

SUBJECT: ADDENDUM TO Concord High School Pool Pak Replacement: Contract #
BSD17001-POOLPAK

ADDENDUM # 4

CHANGES TO DRAWINGS

1. DRAWING M-1

- a. NEW WORK PLAN – MECHANICAL:
 - REVISE note to read:
“ALL EXPOSED RETURN AND SUPPLY DUCTWORK SHALL BE PAINTED, COLOR BY OWNER.”
 - ADD the following note:
“AFTER EXISTING TILE CEILING IS REMOVED ABOVE POOL AREA (by E.C.), EXPOSED CONCRETE CEILING SHALL BE PAINTED. REFER TO CONCRETE CEILING SCOPE OF WORK.”
 - ADD Concrete Ceiling Scope of Work. Refer to attached Sketch SKM-01.

2. DRAWING E-1

- a. DEMOLITION PLAN – ELECTRICAL: ADD the following note:
“E.C. SHALL BE RESPONSIBLE TO REMOVE THE EXISTING DROP CEILING COMPLETE IN THE PPOL AREA. CEILING ABOVE THE BLEACHERS SHALL REMAIN.”
- b. NEW WORK PLAN – ELECTRICAL: ADD the following note:
“ALL CONDUITS EXPOSED ABOVE THE POOL AREA SHALL BE PVC.”

Any questions, please give Dwayne a call at 302-798-3515 ext. 128