

Brandywine School District

12-5-16

TO: ALL OFFERORS

FROM: Carol Riddle
Construction Contract Coordinator

SUBJECT: ADDENDUM TO Concord High School Pool Pak Replacement: Contract #
BSD17001-POOLPAK

ADDENDUM # 5

CHANGES TO SPECIFICATIONS

1. Bid Form Subcontractor List:

- a. ADD the following list to the subcontractor category:

Mechanical
Electrical
Insulation
Painting

2. Section 230600: AIR DISTRIBUTION & ACCESSORIES – HVAC

a. Page 230600-4, Paragraph 2.2, C.1.: REMOVE the following: *Where painting is indicated on drawings, material shall be mill phosphatized (ASTM A591) sheetmetal suitable for immediate painting without further treating other than normal cleaning.*

b. Page 230600-4, Paragraph 2.2 C.2.: REVISE to read:
“2. Aluminum Ductwork: All ductwork shall be aluminum sheet complying with ASTM B209; Alloy 3003, Temper H14.”

CHANGES TO DRAWINGS

1. Drawing M-1

- a. REVISE note to read:

“All exposed return and supply ductwork shall be painted, color by owner.
Manufacturer and Products:

Carboline Company: 1st Coat: Carbothane 133 LH or
Carbothane 133 LV: tint to finish color.

2nd Coat: Carboxane 950 VOC

3rd Coat: Carboxane 950 VOC

Sherwin Williams: 1st Coat: S-W DTM Bonding Primer

2nd Coat: S-W BondPlex Acrylic

3rd Coat: S-W BondPlex Acrylic

b. CLARIFICATION: Bid shall include all work associated with painting existing concrete ceiling. Any/all repair work will be coordinated between awarded contractor and owner at a later date.

Any questions, please give Dwayne a call at 302-798-3515 ext. 128