

ADDENDUM ISSUED BY

ABHA Architects, Inc.  
1621 N. Lincoln Street  
Wilmington, Delaware 19806

NOTICE: Attach this Addendum to the Project Manual for this project. It modifies and becomes a part of the Contract Documents. Work or materials not specifically mentioned herein are to be as described in the main body of the Specifications and as shown on the Drawings.

Acknowledge receipt of the Addendum in the spaced provided on the Bid Form. This Addendum is being transmitted to all contractors who have received Contract Documents. If there are any problems with legibility or content, please contact ABHA Architects, Inc. (302) 658-6426.

ATTACHMENTS

Drawing A-104 - BREEZEWAY PLAN ELEVATION AND DETAILS (For reference only)

CHANGES TO SPECIFICATIONS

SECTION 321823 – TENNIS COURT IMPROVEMENTS

Page 321823-3, Section 2.04, Item A:

Clarification: Only the portion of fence that is removed and replaced for equipment access is to be painted.

SECTION 321823- TENNIS COURT IMPROVEMENTS

Clarifications:

1. The overlay geotextile is to be used at the pavement patch in the center of the court (for the replacement of the net posts), and is to be used for crack repair for any cracks greater than one half inch in width.
2. Work on the breezeway is Not In Contract. Dwg A-104 is attached for contract coordination and is for reference only.
3. The only trench work is for the electrical conduits. There are no new catch basins – only cleaning
4. The full depth reconstruction is only in the center of the tennis courts, which is needed for the replacement of the net posts.
5. The 2.500 square yard allowance for pavement patching is within the areas to be overlaid.
6. The net post and footers are to be replaced.