



TETRA TECH

240 Continental Drive, Suite 200
Newark, Delaware 19713
Tel. (302) 738-7551
Fax (302) 454-5989/5988

Addendum No. 5

Brandywine School District
Wilmington, DE

Bid No.: BSD 18005-GCSERVICES-CARRCROFT

Brandywine School District – Carrcroft Elementary School Addition and Renovation

Tt Project No. 200-15704-17001

Addendum No. 5
to
Drawings and Project Manual

January 29, 2018

To: ALL BIDDERS

This ADDENDUM forms a part of the BIDDING AND CONTRACT DOCUMENTS and modifies the following documents:
Original DRAWINGS dated December 12, 2017
PROJECT MANUAL dated December 12, 2017.

Acknowledge receipt of the ADDENDUM in the space provided on the FORM OF PROPOSAL

This ADDENDUM consists of two (2) pages not including the attachments:

1.0 PROJECT MANUAL – MODIFICATIONS

1.1 None at this time.

2.0 DRAWINGS – MODIFICATIONS

2.1 None at this time.

3.0 CONTRACTOR QUESTIONS:

3.1 **Question:** Sheet A403, details 5, 6 & 7 show rubber treads and risers, however there are no treads or risers listed on the finish schedule / legend. Do stairs 153 & 006 get new treads & risers? If so, please provide product specification for materials desired.

Response: Stair 153; No new treads or risers. Existing to remain.

Stair 006: New treads only: Nora / Norament Stairtreads / Hammered Finish / Color: Platinum Grey 0882

- 3.2 **Question:** Stair 153 calls for RT 1, 2, 3 & 4 – Is this flooring also to be installed on intermediate landing and bottom landing under stairway.
- Response:** Stair 153 **does not** receive new rubber on intermediate or bottom landing. New rubber on top landing only, as shown on Finish Plan.
- 3.3 **Question:** The Type “C” Optima Capz ceiling panels in the cafeteria are not available in 5’ x 5’, and what is the color, please advise?
- Response:** We are changing panel size to be 4’ x 4’. Also, installation is to include painted cold form metal framing to rigidly support Type “C” acoustical panel and grid system approximately 8” below and parallel to sloped metal deck. See sketch revisions attached to this addendum. Panel and exposed fastener “Cap” color is to be white.
- 3.4 **Question:** Please provide a spec for the CFS trusses required at the existing roof over-build.
- Response:** This information is included in spec section 05 40 00.

ATTACHMENT LIST

1. Sketch A/SK-1.02 – Acoustical Panel Detail

END OF ADDENDUM No. 5