

## **ADDENDUM ISSUED BY**

ABHA Architects, Inc.  
1621 N. Lincoln Street  
Wilmington, Delaware 19806

NOTICE: Attach this Addendum to the Project Manual for this project. It modifies and becomes a part of the Contract documents. Work or materials not specifically mentioned herein are to be as described in the main body of the Specifications and as shown on the Drawings.

Acknowledge receipt of the Addendum in the space provided on the Bid Form. This Addendum is being transmitted to all pre-qualified contractors who have received Contract Documents. If there are any problems with legibility or content, please contact ABHA Architects, Inc. (302) 658-6426.

## **ATTACHMENTS:**

- A. DRAWING P-101.3 – FIRST FLOOR PLUMBING PLAN AREA D (1 pg.)

## **GENERAL INFORMATION:**

1. The Bid Form Subcontractor List should list the following Subcontractor Categories:
  - General Works
  - Site
  - Electrical

## **QUESTIONS AND ANSWERS:**

2. On the single drawing E501 are the following panelboards in the this bid pack: LP-1, PP-1 LP-2, LDP, T3, T1, LSDP, DP-1 CDP, AND THE ACCOCATED FEEDERS. Are there any panel schedules?
  - a. Yes. All to be included. No panel schedules yet, breakers will be provide in BPB unless listed on certain panels like “EDP”. Just getting the info-structure in.
3. We need a painting specification for wall and doors.
  - a. Painting not in contract.
4. We need a finish schedule the electric room for painting and ceilings in the hallway.
  - a. Electrical room & hallway finishes not in contract.

## **CHANGES TO DRAWINGS**

### **Plumbing Drawings**

- a. Delete Sheet P-101.3, and replace with Sheet P-101.3 dated 5/1/2018, attached to this Addendum. *Revised underground piping to grease interceptor and domestic water to match civil drawings.*

**END OF ADDENDUM #3**