### Addendum No. 3

Christina School District Eden Support Center 925 Bear-Corbitt Road Bear, Delaware 19701

For the

**Computer Room HVAC Renovations** 

At

**Eden Support Center** 

Contract No. CSD-2012-04

Project No. 11.069

**September 17, 2012** 

Attached is one (1) copy of Addendum No. 3 for each set of bidding documents in your possession. No specifications, Drawings or bid will be considered complete without this Addendum No. 3

### ADDENDUM NO. 3

### A. CHANGES TO SPECIFICATIONS:

### Bid Form

• Replace Bid Form and Liquidated Damages Form.

#### **B. CHANGES TO DRAWINGS:**

- Drawing A100:
  - 1. Revise wall location in plan. Refer to attached Sketch SKA-01.
  - 2. Add wall section to plan. Refer to attached Sketch SKA-02.

### • Drawing M110:

- 1. Add note 10 as follows:
  - "10. Provide supervision and assistance from the local representative for the air handling units to accommodate jobsite disassembly of the modules from the base rail, disassembly of the modules into pieces that will fit through existing building doorways into the training room, and reassembly in place within the new IT room. Provide written certification from the equipment representative that the reassembled units meet original factory specifications to maintain warranty for the owner."

Refer to attached Sketch SKM-01.

### • <u>Drawing E100:</u>

- 1. Add fire alarm control panel to plan. Refer to attached Sketch SKE-01.
- 2. Revised note #13 as follows:

"CONTRACTOR SHALL DISCONNECT THE BRANCH CIRCUIT WIRING FROM THE STAGE PANEL AND LABLE THE CIRCUIT BREAKERS AS SPARE. DISCONNECT AND RETAIN THE LIGHT BAR AND TURN OVER TO OWNER UPON REMOVAL."

Refer to attached Sketch SKE-01.

### 3. Add note #16:

"CONTRACTOR SHALL RELOCATE THE EXISTING FIRE ALARM PANEL AND SMOKE DETECTOR TO THEIR NEW LOCATION. REFER TO DRAWING E110 FOR NEW LOCATIONS. COORDINATE RELOCATION WITH THE FIRE ALARM VENDOR CONTRACTED TO THE DISTRICT. THE EXISTING FIRE ALARM SYSTEM IS MANUFACTURED BY SILENT KNIGHT, MODEL # IFP-1000.

ADDENDUM NO. 3

CONTRACTOR SHALL COORDINATE RELOCATION OF DEVICES AND ADDITION OF NEW DEVICES WITH SIMPLEX GRINNELL 302-325-6300 OR ANACONDA AT 302-319-3776."

Refer to attached Sketch SKE-01.

### • Drawing E110

1. Revised Schedule Note #1 as follows:

"SHUT DOWN OF AIR HANDLING UNITS SHALL BE ACCOMPLISHED BY THE USE OF THE AREA DETECTION SYSTEM (AREA SMOKE DETECTORS). CONTRACTOR SHALL BE RESPONSIBLE FOR ALL FINAL CONNECTIONS TO THE FIRE ALARM CONTROL PANEL AND PROGRAMMING FOR UNIT SHUT DOWN."

Refer to attached Sketch SKE-02.

- 2. Add note to plan for asphalt patch. Refer to attached Sketch SKE-03.
- 3. Add fire alarm panel and smoke detectors to plan. Refer to attached Sketch SKE-02.

### C. BIDDERS QUESTIONS AND CLARIFICATIONS:

- Nick Vacirca of the Christina School District noted the completion date is scheduled for November 1, 2012. **The date is revised to February 1, 2013.**
- A question was asked: What is the height of the wall that will fill the proscenium opening. This was addressed in Addendum #2. **Refer to attached Sketch SKA-01.**
- A question was asked: How will the units enter the building? This was addressed in Addendum #2. **Refer to attached Sketch SKM-01.**
- A question was asked: Replacement of the asphalt along the route of the new electric service?
   Nick Vacirca noted replace with asphalt in areas of excavation. Refer to attached Sketch SKE-03.
- Note to all that there will be an allowance for a generator to power the two electric panels to keep the data center operational during construction of the electric service change over. All agreed that \$5,000 is acceptable. **Allowance shall be carried by the Prime Contractor.**
- A question was asked: How much are the Utility Company fees for the new Service? There will be a \$5,000 allowance for Utility Company fees for the new Service. **Allowance shall be carried by the Prime Contractor.**

Attachments: Bid Form

Liquidated Damages

ADDENDUM NO. 3 -2-

### Christina School District Eden Support Center – Computer Room HVAC Renovations Contract No. CSD-2012-04

### **BID FORM**

For Bids Due:	Thursday, September 20, 2012 @	2:00 pm <b>To:</b>	00 pm To:	
Name of Bidder:		_		
	ss License No.:	Taxpayer ID No.:		
(Other License N	(os.):			
Phone No.: (	) Fax N	o.: ( )		
therewith, that h performed, and exception, herek	the has visited the site and has familiarize that his bid is based upon the material by proposes and agrees to provide all le	ted himself with the loc ls, systems and equipm abor, materials, plant, o	ral conditions under which the Work is to be nent described in the Bidding Documents without equipment, supplies, transport and other facilities	
I / We acknowled schedule impact th			and the price(s) submitted include any cost	
This bid shall remabide by the Bid S	nain valid and cannot be withdrawn for Security forfeiture provisions. Bid Sec	days from urity is attached to this	the date of opening of bids, and the undersigned shal Bid (if required).	
The Owner shall	have the right to reject any or all bids,	and to waive any inforr	mality or irregularity in any bid received.	
This bid is based	upon work being accomplished by the	Sub-Contractors name	ed on the list attached to this bid.	
Should I/We be a	warded this contract. I/We pledge to a	achieve substantial com	upletion of all the work within 90	

calendar days of the Notice to Proceed.

# Christina School District Eden Support Center – Computer Room HVAC Renovations Contract No. CSD-2012-04

### **Liquidated Damages**

The Contractor agrees to pay liquidated damages of the sum of \$250/day for each calendar day the project is not completed within 90 days after notice to proceed.


The undersigned represents and warrants that he has complied and shall comply with all requirements of local, state, and national laws; that no legal requirement has been or shall be violated in making or accepting this bid, in awarding the contract to him or in the prosecution of the work required; that the bid is legal and firm; that he has not, directly or indirectly, entered into any agreement, participated in any collusion, or otherwise taken action in restraint of free competitive bidding.

Upon receipt of written notice of the acceptance of this Bid, the Bidder shall, within twenty (20) calendar days, execute the agreement in the required form and deliver the Contract Bonds, and Insurance Certificates, required by the Contract Documents.

By	Ve are an Individual / a Partnership / a Corporation		Trading as	
2,	(Individual's / General Partner's / Corp			
	(State of Corporation)			
	ss Address:			
Witnes	s:	By:	( Authorized Signature )	
( SEA	L)		(Title)	
		Date	:	

### **ATTACHMENTS:**

Sub-Contractor List Payment Bond Performance Bond



ADDENDUM #3 REFERENCE DWG. A100




## COMPUTER ROOM HVAC RENOVATIONS EDEN SUPPORT CENTER


PROJECT NO.

SCALE: AS NOTED

DRAWN BY: WJS

DATE: 09/17/12





This drawing or specification and the design features or resulting construction disclosed are the property of Furlow Associates, Inc., and shall not be reproduced in any way without written permission.

## DRAWING NOTES

- COORDINATE CONDENSATE DRAIN LINE WITH EXISTING BOILER BREACHING AND EXPANSION TANKS ABOVE BOILERS.
- MOUNT CONDENSATE DRAIN LINE TO MAINTAIN ACCESS FOR CRAWL SPACE OPENING IN FOUNDATION WALL.
- (3) REFER TO ARCHITECTURAL DRAWINGS FOR PARTITION, DOOR, AND CEILING DETAILS.
- (4) LOCATE RS/RL PIPING BELOW CEILING.
- INTERFACE WALL MOUNTED TEMPERATURE SENSOR WITH EACH AIR HANDLING UNIT SYSTEM AND EXISTING DDC CONTROL PANEL. REFER TO PROJECT MANUAL FOR SEQUENCE OF OPERATION.
- 6 INTERFACE WALL MOUNTED TEMPERATURE SENSOR WITH EXISTING DDC CONTROL PANEL FOR HIGH LIMIT MONITORING AND ALRAM.
- 7 PROVIDE 1-1/8" VERTICAL SUCTION RISER AT EVAPORATOR COIL CONNECTION IN ACCORDANCE WITH UNIT MANUFACTURER'S RECOMMENDATIONS.
- 8 PROVIDE STEAL BEAMS UNDER AIR HANDLING UNIT AS DETAILED ON THE STRUCTURAL DRAWINGS. TYPICAL FOR THREE UNITS.
- PROVIDE 1/2" WELDED WIRE MESH SCREEN IN REMOVABLE FRAME FULL SIZE OF RETURN AIR OPENING ON UNIT. TYPICAL FOR THREE UNITS.

PROVIDE SUPERVISION AND ASSISTANCE FROM THE LOCAL REPRESENTATIVE FOR THE AIR HANDLING UNITS TO ACCOMMODATE JOBSITE DISASSEMBLY OF THE MODULES FROM THE BASE RAIL, DISASSEMBLY OF THE MODULES INTO PIECES THAT WILL FIT THROUGH EXISTING BUILDING DOORWAYS INTO THE TRAINING ROOM, AND REASSEMBLY IN PLACE WITHIN THE NEW IT ROOM. PROVIDE WRITTEN CERTIFICATION FROM THE EQUIPMENT REPRESENTATIVE THAT THE REASSEMBLED UNITS MEET ORIGINAL FACTORY SPECIFICATIONS TO MAINTAIN WARRANTY FOR THE OWNER.

ADDENDUM #3 REFERENCE DWG. M110



### COMPUTER ROOM HYAC RENOVATIONS EDEN SUPPORT CENTER

PROJECT NO.


COPYRIGHT 2011 FURLOW ASSOCIATES, INC.


PARTIAL FLOOR PLANS - MECHANICAL

SCALE: AS NOTED

DRAWN BY: RLL

DATE: 09/17/12





## **DEMOLITION NOTES**

- CONTRACTOR SHALL DISCONNECT THE BRANCH CIRCUIT WIRING FROM THE STAGE PANEL AND LABLE THE CIRCUIT BREAKERS AS SPARE.

  DISCONNECT AND RETAIN THE LIGHT BAR AND TURN OVER TO OWNER UPON REMOVAL.
- 14) CONTRACTOR SHALL RELOCATE THE EXIST. HORN/STROBE TO THE NEW WALL. REFER TO DRAWING E110 FOR NEW LOCATION.

  COORDINATE RELOCATION WITH THE FIRE ALARM VENDOR CONTRACTED TO THE DISTRICT.
- (5) CONTRACTOR SHALL TEMPORARLLY SUPPORT THE FIXTURES TO THE STEEL ABOVE FOR REMOVAL OF THE EXISTING CEILING. REFER TO DRAWING E110 FOR REINSTALLATION.
- CONTRACTOR SHALL RELOCATE THE EXISTING FIRE ALARM PANEL AND SMOKE DETECTOR TO THEIR NEW LOCATION. REFER TO DRAWING E110 FOR NEW LOCATIONS. COORDINATE RELOCATION WITH THE FIRE ALARM VENDOR CONTRACTED TO THE DISTRICT. THE EXISTING FIRE ALARM SYSTEM IS MANUFACTURED BY SILENT KNIGHT, MODEL # IFP-1000. CONTRACTOR SHALL COORDINATE RELOCATION OF DEVICES AND ADDITION OF NEW DEVICES WITH SIMPLEX GRINNELL 302-325-6300 OR ANACONDA AT 302-319-3776.

ADDENDUM #3 REFERENCE DWG. E100



# COMPUTER ROOM HYAC RENOVATIONS EDEN SUPPORT CENTER

PROJECT NO.

|| 069


COPYRIGHT 2011
FURIOW ASSOCIATES, INC.


PARTIAL FLOOR PLANS - DEMOLITION ELECTRICAL

SCALE: AS NOTED

DRAWN BY: WJS

DATE: 09/17/12





## SCHEDULE NOTES:

(1) SHUT DOWN OF AIR HANDLING UNITS SHALL BE ACCOMPLISHED BY THE USE OF THE AREA DETECTION SYSTEM (AREA SMOKE DETECTORS). CONTRACTOR SHALL BE RESPONSIBLE FOR ALL FINAL CONNECTIONS TO THE FIRE ALARM CONTROL PANEL AND PROGRAMMING FOR UNIT SHUT

COORDINATE THE CONDUIT RUN TO THE ACC UNITS THROUGH THE WALL WITH THE MECHANICAL

ADDENDUM #3 REFERENCE DWG. E110



### COMPUTER ROOM HYAC RENOVATIONS EDEN SUPPORT CENTER 11.069 PARTIAL FLOOR PLANS - ELECTRICAL

SCALE:	AS NOTED	
DRAWN BY:	WUS	
DATE:	09/17/12	

REV.	DESCRIPTION	DATE		
SKE-Ø2				

