



*For Your Health & Safety<sup>sm</sup>*

# COMPLIANCE ENVIRONMENTAL, INC.

150 South Bradford Street, Dover, Delaware 19904

Phone: 302-674-4427 Fax: 302-674-4429

[www.compliancecanhelp.com](http://www.compliancecanhelp.com)

## **ADDENDUM No. 2**

**April 29, 2015**

**Project:** Specification for 2015 Asbestos Abatement for the Locker Replacement Project at the William Henry Middle School.

**Bid Due:** **Tuesday, May 5, 2015, at 2:00 PM (Local Time) (Unchanged)**  
**Bids are due at the Capital School District, District Office,**  
**198 Commerce Way, Dover, Delaware 19904.**  
Bids will be publicly opened at that time.

The following changes are hereby made to the bidding documents and project specifications:

1. **Removal Procedures (Section 01013):** For all asbestos abatement activities except for floor tile removal on the project, all work areas shall consist of two (2) layers of 6-mil plastic sheeting as critical barriers and two (2) layers of 6-mil plastic sheeting on floors, walls and ceilings. For floor tile removal, all work areas shall consist of two (2) layers of 6-mil plastic sheeting as critical barriers and two (2) layers of 6-mil plastic sheeting on walls and ceilings.

If you have any further comments, please contact Compliance Environmental (302-674-4427) in writing within five (5) days. Therefore, these minutes shall become part of Addendum No. 2 and therefore binding on the Contractor for this project.

**COMPLIANCE ENVIRONMENTAL, INC.**

Valentino P. De Rocili, Ph.D., CHMM

Project Designer

Senior Principal Consultant

[vderocili@compliancecanhelp.com](mailto:vderocili@compliancecanhelp.com)

**[ END OF ADDENDUM No. 2 ]**