



315 S. Chapel St.  
Newark, DE 19711

Phone  
302.738.7172

Fax  
302.738.7175

[www.dedc-eng.com](http://www.dedc-eng.com)

PRE-BID MEETING SUMMARY  
DELAWARE ARMY NATIONAL GUARD SITE FIRE ALARM UPGRADE  
FMO-DEARNG # 15-008  
ADDENDUM #5

QUESTIONS:

1. Are lock boxes required and if so, do they have to be monitored?  
RESPONSE – Yes lock boxes are required, and no they do not have to be monitored.
  
2. Are all drops to pull stations and AV's to be recessed in the wall?  
RESPONSE – In all walls and ceilings that can be fished use the wire specified. In any wall or ceiling that can't be fished i.e. filled masonry or concrete. Surface mount the wire with metallic wire mold.
  
3. Is red MC fire cable permitted above ceilings and inside walls?  
RESPONSE – Red MC Cable is not permitted.

Summarized By: DEDC, LLC  
Mike Finamore  
Date: 9/9/15