

**ADDENDUM NO. 2
ELECTRICAL IMPROVEMENTS AT THE DELAWARE ARMY NATIONAL GUARD
SCANNELL READINESS CENTER
DE ARNG CONTRACT NO. 22-2013
FE&ES Comm.: 13-1116**

- 1.0 This Addendum, Addendum No. 2, shall be made part of the Project Manual and Drawings dated July 25, 2014 for the Electrical Improvements at the Delaware Army National Guard Scannell Readiness Center.
- 2.0 Any provision in any of the Contract Documents which may be in conflict or be inconsistent with the contents of this Addendum shall be void to the extent of such conflicts or inconsistency.
- 3.0 Bid Date has not changed. Bids will be received by the Delaware Army National Guard at the Security Officers desk in the Main Lobby of the Armed Forces Reserve Center located at 250 Airport Road, New Castle, Delaware, 19720-1502, **until 2:00 PM local time on Thursday, September 11, 2014**. Valid driver's license will be required for site access, front desk where all visitors are required to sign in at the Security Desk. Bidder bears the risk of late delivery. Any bids received after the stated time will be returned unopened. **Allow ample time to enter the facility since the site is secure and each vehicle entering the facility will need to pass through security.**
- 4.0 Changes to prior Addenda
 - 4.1. Working hours are 7:00 a.m. to 4:00 p.m. Monday through Friday except for the following Mondays when the facility is closed and the contractor will not be able to work in the building. Those days are: Oct 10, 13, 27; Nov 10, 11, 27, 28; Dec 8, 25, 26; Jan 1, 5, 16, 19; Feb 2, 13, 16; Mar 2, 16. Additional hours must be arranged with the Owner in advance. All shutdowns shall be conducted on weekdays and at the convenience of the owner. Shutdowns must be scheduled and approved by the owner a minimum of two weeks in advance.
 - 4.2 Section 00 41 13 Bid Form: **Replace** the current bid form with the revised bid form which includes a revised Non-Collusion Page 4.
- 5.0 Changes to Specifications
 - 5.1 Section 00 81 13 General Requirements
 - A. **Add** the following new Articles 13.7 & 13.8
 - 13.7 REPORTING
 - 13.7.1 Contractor who is awarded the contract must report contract amounts awarded to all listed subcontractors. Information to report is included in the chart below. If subcontractor is considered a minority, women or veteran owned business, please identify if they are registered with the State of Delaware, Office of Supplier Diversity.

SUBCONTRACTOR CATEGORY	SUBCONTRACTOR NAME	SUBCONTRACTOR CONTRACT AMOUNT	IS SUBCONTRACTOR MINORITY, WOMEN OR VETERAN OWNED?

13.8 BUY AMERICAN ACT

13.8.1 This contract requires compliance with the Buy American Act (41 U.S.C. 10.) The Buy American Act gives preference to domestic end products and domestic construction material. To verify compliance with this Section, Contractor is required to provide proof, acceptable to the Owner, that all major equipment and material installed on the project was manufactured in the United States.

Section 26 32 13 Emergency/Standby Generator

A. Article 3.08 **Delete** paragraph in its entirety. There will be no service contract for this generator.

6.0 Changes to Drawings: There are no Changes to Drawings.

7.0 Questions/Clarifications

Q1 Addendum 1 door detail SKA-1 note six talks about electrical conduit to the door. Do these doors have electric locks within? If so need spec.

A1: There is no electric to this door.

Original on File

Edward Fayda, P.E.

EF/ef
 13-1116 Addendum No 2
 Attachments: Specification Section 00 41 13 Bid Form

cc: All Registered Plan Holders
 P File

**ELECTRICAL IMPROVEMENTS
DELAWARE ARMY NATIONAL GUARD
SCANNELL READINESS CENTER
GOVERNOR BACON HEALTH CENTER, DELAWARE CITY, DE
DE ARNG PROJECT #: 22-2013**

BID FORM

For Bids Due: 2:00 p.m. September 11, 2014

To: CPT. Eugene Bledsoe
AFRC-DEARNG-FMO
250 Airport Road
New Castle, DE 19720

Provide 3 Copies

Name of Bidder: _____

Delaware Business License No.: _____ **Taxpayer ID No.:** _____

(Other License Nos.): _____

Phone No.: () _____ - _____ **Fax No.:** () _____ - _____

The undersigned, representing that he has read and understands the Bidding Documents and that this bid is made in accordance therewith, that he has visited the site and has familiarized himself with the local conditions under which the Work is to be performed, and that his bid is based upon the materials, systems and equipment described in the Bidding Documents without exception, hereby proposes and agrees to provide all labor, materials, plant, equipment, supplies, transport and other facilities required to execute the work described by the aforesaid documents for the lump sum itemized below:

BASE BID: Provide new Secondary Feeders, Switchboards, Motor Controls and Distribution Equipment Modifications in Boiler Room.

Amount: _____ (\$ _____)

ALTERNATES

Alternate prices conform to applicable project specification section. Refer to specifications for a complete description of the following Alternates. An "ADD" or "DEDUCT" amount is indicated by the crossed out part that does not apply.

Alternate No. 1: Provide branch circuit panel and feeder replacement throughout the 1st and 2nd floors of the Armory Building.

Add: _____ (\$ _____)

Alternate No. 2: Provide 100kW diesel gas generator and associated appurtenances.

Add: _____ (\$ _____)

Alternate No. 3: Additional costs for disposal of PCB filled transformers in lieu of non-PCB filled transformers. To be awarded during construction after testing of transformers.

Add: _____ (\$ _____)

ALLOWANCE ACKNOWLEDGEMENT: There are no Allowances.

UNIT PRICES: There Are No Unit Prices.

**ELECTRICAL IMPROVEMENTS
DELAWARE ARMY NATIONAL GUARD
SCANNELL READINESS CENTER
GOVERNOR BACON HEALTH CENTER, DELAWARE CITY, DE
DE ARNG PROJECT #: 22-2013**

BID FORM

I/We acknowledge Addenda numbered 1, 2_____ and the price(s) submitted includes any cost/schedule impact they may have.

This bid shall remain valid and cannot be withdrawn for 30 days from the date of opening of bids, and the undersigned shall abide by the Bid Security forfeiture provisions. Bid Security is attached to this Bid.

The Owner shall have the right to reject any or all bids, and to waive any informality or irregularity in any bid received.

This bid is based upon work being accomplished by the Sub-Contractors named on the list attached to this bid.

Should I/We be awarded this contract, I/We pledge to achieve substantial completion of all the Base Bid work within 180 calendar days of the Notice to Proceed.

The undersigned represents and warrants that he has complied and shall comply with all requirements of local, state, and national laws; that no legal requirement has been or shall be violated in making or accepting this bid, in awarding the contract to him or in the prosecution of the work required; that the bid is legal and firm; that he has not, directly or indirectly, entered into any agreement, participated in any collusion, or otherwise taken action in restraint of free competitive bidding.

Upon receipt of written notice of the acceptance of this Bid, the Bidder shall, within twenty (20) calendar days, execute the agreement in the required form and deliver the Contract Bonds, and Insurance Certificates, required by the Contract Documents.

I am / We are an Individual / a Partnership / a Corporation

By _____ Trading as _____
(Individual's / General Partner's / Corporate Name)

(State of Corporation)

Business Address: _____

Witness: _____ By: _____
(SEAL) (Authorized Signature)

(Title)

Date: _____

- ATTACHMENTS**
Sub-Contractor List
Non-Collusion Statement
Bid Security
(Others as Required by Project Manuals)

**ELECTRICAL IMPROVEMENTS
DELAWARE ARMY NATIONAL GUARD
SCANNELL READINESS CENTER
GOVERNOR BACON HEALTH CENTER, DELAWARE CITY, DE
DE ARNG PROJECT #: 22-2013**

BID FORM

SUBCONTRACTOR LIST

In accordance with Title 29, Chapter 6962 (d)(10)b Delaware Code, the following sub-contractor listing must accompany the bid submittal. The name and address of the sub-contractor **must be listed for each category** where the bidder intends to use a sub-contractor to perform that category of work. In order to provide full disclosure and acceptance of the bid by the *Owner*, **it is required that bidders list themselves as being the sub-contractor for all categories where he/she is qualified and intends to perform such work.**

<u>Subcontractor Category</u>	<u>Subcontractor</u>	<u>Address (City & State)</u>	<u>Subcontractors tax payer ID # or Delaware Business license #</u>
1. <u>Electrical</u>	_____	_____	_____
		_____	_____
2. <u>Excavation</u>	_____	_____	_____
		_____	_____
3. <u>Concrete</u>	_____	_____	_____
		_____	_____
4. <u>Doors & Hardware</u>	_____	_____	_____
		_____	_____
5. _____	_____	_____	_____
		_____	_____
6. _____	_____	_____	_____
		_____	_____

**ELECTRICAL IMPROVEMENTS
DELAWARE ARMY NATIONAL GUARD
SCANNELL READINESS CENTER
GOVERNOR BACON HEALTH CENTER, DELAWARE CITY, DE
DE ARNG PROJECT #: 22-2013**

BID FORM
NON-COLLUSION and EPLS DISCLOSURE STATEMENT

This is to certify that the undersigned bidder has neither directly nor indirectly, entered into any agreement, participated in any collusion or otherwise taken any action in restraint of free competitive bidding in connection with this proposal submitted this date to the Office of Management and Budget, Division of Facilities Management.

AFFIRMATION: Within the past five years, has your firm, any affiliate, any predecessor company or entity, owner, Director, officer, partner or proprietor been the subject of a Federal, State, Local government suspension or debarment?

YES _____ NO _____ If yes, please explain (use separate page and include with Bid Form.)

All the terms and conditions of DEARNG CONTRACT NO. 22-2013 have been thoroughly examined and are understood.

NAME OF BIDDER: _____

AUTHORIZED REPRESENTATIVE (TYPED): _____

AUTHORIZED REPRESENTATIVE (SIGNATURE): _____

TITLE: _____

ADDRESS OF BIDDER: _____

PHONE NUMBER: _____

Sworn to and Subscribed before me this _____ day of _____ 20____.

My Commission expires _____. NOTARY PUBLIC _____.

THIS PAGE MUST BE SIGNED AND NOTARIZED FOR YOUR BID TO BE CONSIDERED.