

**ADDENDUM NO. 3
ELECTRICAL IMPROVEMENTS AT THE DELAWARE ARMY NATIONAL GUARD
DUNCAN READINESS CENTER
41 CORPORATE CIRCLE, NEW CASTLE, DELAWARE 19720
DEARNG CONTRACT NO. 03-2014
FE&ES Comm.: 13-1117
Date of Issue: September 8, 2014**

- 1.0 This Addendum, Addendum No. 3, shall be made part of the Project Manual and Drawings dated August 11, 2014 for the Electrical Improvements at the Delaware Army National Guard Duncan Readiness Center.
- 2.0 Any provision in any of the Contract Documents which may be in conflict or be inconsistent with the contents of this Addendum shall be void to the extent of such conflicts or inconsistency.
- 3.0 Bid Date has not changed. Sealed bids for **DEARNG Contract No. 03-2014** – Duncan Readiness Center Electrical Upgrades, will be received by the Delaware Army National Guard at the Security Officers desk in the Main Lobby of the Armed Forces Reserve Center, 250 Airport Road, New Castle, Delaware, 19720 until **2:00 PM local time on September 12, 2014**, at which time they will be publicly opened and read aloud in the Multi-Purpose Room. **Allow ample time to enter the facility since the site is secure and each vehicle entering the facility will need to pass through security.**
- 4.0 Changes to prior Addenda
 - 4.1. There are no Changes to prior Addenda.
- 5.0 Changes to Specifications
 - 5.1 Section 26 32 13, Article 2.6A, Refer to Addendum #3 article 6.1.A below.
- 6.0 Changes to Drawings:
 - 6.1 Drawing E-3 Single Line Diagram- New Work (ADD ALTERNATE #2)
 - A. Change Generator Output Circuit Breaker to 3P-400A Frame with 225A trip. Breaker shall be Electronic, fully adjustable with L,S and I settings. Settings to be determined by Power System Study.
 - B. Change feeder from generator to ATS from Feeder Type 2 to new Feeder Type 13. Type 13 Feeder shall be 2-4" C; 1 w/4-300kCMIL & 1-#1/0GND and 1- 4" C Spare.
 - C. Omit 3P-400A Nema 1 Enclosed Emergency Breaker ahead of ATS.
 - D. Provide new generator emergency stop switch adjacent to Emergency side of ATS. Provide connections to generator per manufacturer's instructions.
- 7.0 Questions/Clarifications
 - 7.1 There are no Questions/Clarifications

END OF ADDENDUM #3

EF/ef
13-1117 Add No 3

cc: All Registered Plan Holders

