

**ADDENDUM NO. 2
TELECOMMUNICATION SYSTEMS RELOCATION
AT THE
DELAWARE ARMY NATIONAL GUARD RIVER ROAD TRAINING FACILITY
1197 RIVER ROAD, NEW CASTLE DE 19720
DEARNG CONTRACT NO. 05-2014
FE&ES Comm.: 14-1129A
Date of Issue: September 5, 2014**

- 1.0 This Addendum, Addendum No. 2, shall be made part of the Project Manual and Drawings dated August 8, 2014 for the Telecommunication Systems Relocation at the Delaware Army National Guard River Road Training Facility.
- 2.0 Any provision in any of the Contract Documents which may be in conflict or be inconsistent with the contents of this Addendum shall be void to the extent of such conflicts or inconsistency.
- 3.0 Bid Date has not changed. Sealed bids for DEARNG **Contract No. 05-2014** – Telecommunication Systems Relocation At The Delaware Army National Guard River Road Training Facility 1197 River Road, New Castle De 19720 will be received by the Delaware Army National Guard at the Security Officers desk in the Main Lobby of the Armed Forces Reserve Center located at 250 Airport Road, New Castle, Delaware, 19720-1502, until **1:00 PM local time on Thursday, September 18, 2014**, at which time they will be publicly opened and read aloud in the Multipurpose Room located next to the main lobby. Valid driver's license will be required for site access, front desk where all visitors are required to sign in at the Security Desk. Bidder bears the risk of late delivery. Any bids received after the stated time will be returned unopened. **Contractors are reminded to provide ample time to gain access to this secure site.**
- 4.0 Changes to prior Addenda
4.1. There are no Changes to prior Addenda.
- 5.0 Changes to Specifications
5.1 A Geotechnical report is being prepared and will be released under a subsequent Addendum.
- 6.0 Changes to Drawings:
6.1 There are no Changes to Drawings.
- 7.0 Questions/Clarifications
Q1 I did not notice any termination material for the 625 coax cables, could you verify if they are to be terminated please?
A1: Coaxial Services will be terminated in accordance with DTI requirements and provided with Protection Blocks. At this time, the Coaxial Services will be dark.

END OF ADDENDUM #2

EF/ef
14-1129A Add No 2

cc: All Registered Plan Holders
P File

