



STATE OF DELAWARE
DEPARTMENT OF CORRECTION
BUREAU OF MANAGEMENT SERVICES / PURCHASING
245 MCKEE ROAD
DOVER, DELAWARE 19904

TO: ALL OFFERERS

FROM: PURCHASING SERVICES ADMINISTRATOR

SUBJECT: RESPONSES TO ITB QUESTIONS FOR PROPOSAL NO.:
DOC1429-DISHWASH, DISHMACHINES FOR JAMES T. VAUGHN CORRECTIONAL CENTER

ADDENDUM # 2– October 14, 2013

DE Department of Correction submits the following Consolidated Response to Questions submitted post site visit conducted Wednesday, October 9, 2013. All other terms and conditions of the RFP remain unchanged.

QUESTION #1

Question: Who is disconnecting and removing the existing Dishwashers?

Answer: DE Department of Correction, Facilities Maintenance.

QUESTION #2

Question: What part of the duct work will remain for the new Dishwashers?

Answer: Ductwork will be removed to the ceiling level.

QUESTION #3

Question: Who is removing the steam piping coming from the Ceiling?

Answer: Steam pipes are in the floor, not the ceiling. DOC Facilities Maintenance will be removing.

QUESTION #4

Question: Is the Institution providing the disconnects for the machines and is the service large enough?
REQUIREMENTS:

Dishwasher: 80 Amps. 100 Amp Breaker

Booster: 89 Amps. 125 Amp Breaker

Blower Dryer: 17 Amps. 25 Amp Breaker

Answer: DOC Facilities Maintenance will be providing the disconnects. The service is large enough.

QUESTION #5

Question: Will the final connections from the disconnects be brought to within 6'-0" of the dish machine?

Answer: Unknown until bids opened and full specifications of equipment are known.

QUESTION #6

Question: What are the hours allowed to perform work in the dish rooms?

Answer: This question will be discussed after bid opening and a mutually agreeable schedule developed.
The JTVCC Food Service area operates 12am until 7:30pm daily.