

September 7, 2012

TO: ALL OFFERERS

FROM: **STATE OF DELAWARE
DEPARTMENT OF TRANSPORTATION
CONTRACT ADMINISTRATION**

SUBJECT: CLARIFICATION TO INVITATION TO BID - CONTRACT NO. **DOT1213-
GEN_REPAIR, GENERATOR MAINTENANCE & REPAIR**

ADDENDUM # 1 - CLARIFICATION

In TECHNICAL SPECIFICATIONS, Section A, Preventive Maintenance, in the heading for # 12. Load Tests on page 23 of the solicitation, DelDOT offers the following clarification of the requested service(s):

The requested load test is not intended to be for the generator's starting batteries only. The awarded contractor(s) will be required to load-test the output capacity of the back-up generator(s) to the facility to a minimum 85% rating for a minimum of one (1) hour. If the load test results are unsatisfactory after the hour, the contractor will be expected to continue to load-test the facility back-up generator for an additional hour.

All other terms and conditions remain the same.

If you have any questions, please contact me at 302-760-2031 or at dot-ask@state.de.us