




Kitchen Replacements at Lavery Lane Addendum #3; RFI's

This addendum modifies the contract documents prepared by The Delaware State Housing Authority, Inc. for this project and is incorporated into said documents in its entirety.

- AD 3.1. Are we allowed to use the tenant's electricity or do we have to supply our own? **NO. CONTRACTOR MUST SUPPLY THEIR OWN ELECTRICITY SOURCE**
- AD 3.2. Is a working kitchen required each evening since they are occupied apartments? **SINK AND REFRIGERATOR MUST BE IN WORKING ORDER EACH EVENING. PLAN TO INSTALL NEW REFRIGERATOR 1-2 DAYS PRIOR TO BEGINNING APARTMENT WORK SO PERISHABLES CAN BE TRANSFERRED FROM OLD TO NEW. TEMPORARY LOCATION SHOULD BE AGREED WITH DSHA MANAGEMENT AND TENANT AND REFRIGERATOR PLACED ON TEMPORARY COASTERS TO FACILITATE MOVEMENT TO FINAL LOCATION.**
- AD 3.3. Are we responsible for taking items out of existing cabinets and refrigerators? **NO. DSHA WILL COORDINATE MOVEMENT OF EXISTING ITEMS WITH TENANT SUCH THAT CABINETS AND APPLIANCES ARE EMPTY FOR BEGINNING OF WORK.**
- AD 3.4. When hiring the Section 3 employees, are we required to supply them with transportation to and from the site? **NO**
- AD 3.5. Are we responsible for disposing of old appliances off site? **YES. NOTE THAT ALL REQUIREMENTS BY LOCAL AND FEDERAL AUTHORITIES FOR RECOVERY/DISPOSAL OF REFRIGERANTS MUST BE FOLLOWED. KEEP RECEIPTS AS PART OF PROJECT RECORDS.**
- AD 3.6. The pictures on the prints did not show a drawer base in the 3 bedroom apartments. Is a drawer base required? **YES, A DRAWER BASE IS REQUIRED. SEE REVISION TO DRAWING 3/A201 BELOW INDICATING LOCATION:**



DWG 3/A201

Brandywine Design Guild, LLC

5 Meadow Glen Lane Wilmington, DE 19810 ■ Phone: 302.985.7038 Fax: 302.475.1006 ■ BDGLLC@verizon.net



AD 3.7. ADA unit 28 shows Apl-1. Is this supposed to be Apl-4 which is insinuated by the picture? **ADA UNIT #28 SHOULD RECEIVE AN APL-4 SIDE BY SIDE TYPE REFRIGERATOR.**

AD 3.8. Apartments 54 & 56 are missing from the Matrix. Are these 2 units not getting done? **UNITS 54 & 56 TO BE COMPLETED. SEE REVISED MATRIX BELOW INDICATING THEIR REQUIREMENTS.**

APPLIANCE MATRIX - REV 7/14/16

UNIT #	CABINETS	CONTERTOPS	WALL BACKSPLSHES	SINK	REFRIGERATOR	RANGE	RANGE HOOD	UNIT #	CABINETS	CONTERTOPS	WALL BACKSPLSHES	SINK	REFRIGERATOR	RANGE	RANGE HOOD	UNIT #	CABINETS	CONTERTOPS	WALL BACKSPLSHES	SINK	REFRIGERATOR	RANGE	RANGE HOOD
3	Y	Y	Y	Y	Y (1)	Y	Y	20	Y	Y	Y	Y	Y	Y	Y	37	Y	Y	Y	Y	Y	Y	Y
4	Y	Y	Y	Y	Y	Y	Y	21	Y	Y	Y	Y	Y	Y	Y	38	Y	Y	Y	Y	Y	Y	Y
5	N	N	N	N	N	N	N	22	Y	Y	Y	Y	Y	Y	Y	39	N	N	N	N	N	Y	Y
6	Y	Y	Y	Y	Y	Y	Y	23	N	Y	Y	Y	N	N	N	40	N	N	N	N	Y	Y	Y
7	Y	Y	Y	Y	Y	Y	Y	24	Y	Y	Y	Y	Y	Y	Y	41	Y	Y	Y	Y	Y	Y	Y
8	Y	Y	Y	Y	Y (1)	Y	Y	25	N	N	Y	N	N	Y	N	42	Y	Y	N	Y	Y	Y	N
9	Y	Y	Y	Y	(2)	N	Y	26	Y	N	Y	N	N	N	N	43	Y	Y	Y	Y	Y (1)	Y	Y
10	Y	Y	Y	Y	(2)	N	N	27	Y	Y	Y	Y	N	Y	Y	44 (ADA)	N	N	N	N	N	Y	Y
11	Y	Y	Y	Y	Y	Y	Y	28 (ADA)	Y (4)	Y	Y	Y	Y (3)	Y	Y	45	Y	Y	Y	N	Y	Y	Y
12	Y	Y	Y	Y	N	Y	Y	29	Y	Y	Y	Y	Y	Y	Y	46 (ADA)	Y (4)	N	N	N	Y	Y	N
13 (ADA)	Y (4)	Y	Y	Y	Y	Y	Y	30	Y	Y	Y	Y	Y	Y	Y	47	Y	Y	Y	Y	Y (1)	Y	Y
14	Y	Y	Y	Y	N	Y	Y	31	Y	Y	Y	Y	Y	Y	Y	48	Y	Y	Y	Y	Y (1)	Y	Y
15 (ADA)	Y (4)	Y	Y	Y	Y	Y	Y	32	Y	Y	Y	Y	Y	Y	Y	49	N	N	N	N	Y (1)	Y	Y
16	Y	Y	Y	Y	Y	Y	Y	33	N	N	N	N	Y	Y	Y	50	Y	Y	Y	Y	(2)	N	Y
17	Y	Y	Y	Y	(2)	N	N	34	Y	Y	Y	Y	Y	Y	Y	51	Y	Y	Y	Y	Y	Y	Y
18	N	N	N	N	N	N	N	35	Y	Y	Y	Y	Y	Y	Y	52	N	N	N	N	(2)	N	N
19	N	N	N	N	(2)	N	N	36	Y	Y	Y	Y	Y	Y	Y	54	Y	Y	Y	Y	Y (3)	Y	Y
																56	Y	Y	Y	Y	Y (3)	Y	Y

NOTES:

- (1) - RELOCATE EXISTING REFRIGERATOR TO ANOTHER APARTMENT
- (2) - RECEIVE RELOCATED REFRIGERATOR
- (3) - SALVAGE EXISTING REFRIGERATOR FOR DSHA STOCK. COORDINATE STORAGE LOCATION WITH SITE MANAGER
- (4) - BASE CABINETS INSTALLED IN ADA UNITS MUST BE ADA COMPLIANT HEIGHT (34" TO TOP OF COUNTER) AND HAVE HAVE 9" KICK SPACE AT CABINET BOTTOM

-- END OF ADDENDUM #3 --