

Addendum #3

Date: November 16, 2015

Project: Warren Franklin East & West Window Replacement

Contract: FD-14-098

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

Clarifications:

1. None.

Changes to Specifications:

1. None.

Changes to Drawings:

1. None.

General Information:

1. None.

Questions and Answers:

1. **Question:** 1/4" Corian is specified for the window sills. Corian strongly discourages 1/4" material in horizontal applications. Would 1/2" Corian be allowed to be used?

Answer: The drawings graphically indicate a w.r. plywd blocking and thinner solid surface, no thicknesses. The Note 7 indicates the minimum thickness of the stool of 3/4". The minimum thickness of solid surface shall be 1/2" thick.

END