

Addendum #4

Date: November 17, 2015

Project: Warren Franklin East & West Window Replacement

Contract: FD-14-098

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

Clarifications:

1. None.

Changes to Specifications:

1. None.

Changes to Drawings:

1. None.

General Information:

1. None.

Questions and Answers:

1. **Question:** Drawing A10-03 Detail 2 - Insulated Spandrel Unit - The "Mapes" porcelain on aluminum finish specified for the panel interior has been discontinued. Please provide an alternate finish to be priced for the panel interior.

Answer: Revise the Insulated Spandrel Unit to be: Mapes Laminated MapeShape panel, Exterior - Clear Anodized Class 1, Interior - Clear Anodized Class 1, Exterior Substrate - Impact Layer, Exterior Core - Isocyanurate, Secondary Exterior Substrate - Impact Layer, Interior Core - Isocyanurate, Interior substrate - Solid Plastic, Overall panel thickness - 2", Glazing Leg Thickness - 1", R-value - 13.31

END