



Addendum # 2

Date: April 18, 2019

Project: ECHS Fit-Out Phase 1 at R.S. Grossley Hall

Contract: PC-18-021

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

Changes to Drawings:

1. *Drawing 1.0 (No revised drawing or sketch issued to reflect this change)–*
 - a. Revised the sheet index as follows:
 - 1.0 COVER SHEET
 - 1.1 CODE COMPLIANCE
 - 1.2 TYPICAL MOUNTING HEIGHTS
 - 2.0 DEMOLITION PLANS
 - 2.1 DEMOLITION CEILING PLANS
 - 3.0 NEW FLOOR PLANS
 - 3.1 REFLECTED CEILING PLANS
 - 3.2 BATHROOM PLAN AND ELEVATIONS
 - 7.0 NEW FINISHES PLAN
 - MP-0 MECHANICAL AND PLUMBING COVER SHEET
 - MP-1 FIRST FLOOR MECHANICAL AND PLUMBING PLANS
 - 9.0 ELECTRICAL SYMBOLS, ABBREVIATIONS, AND NOTES
 - 9.1 ELECTRICAL FIRST FLOOR PLAN
 - 9.2 ELECTRICAL SECOND FLOOR DEMOLITION PLAN
 - 9.3 ELECTRICAL LIGHTING SECOND FLOOR DEMOLITION PLAN
 - 9.4 ELECTRICAL SECOND FLOOR PLAN
 - 9.5 ELECTRICAL LIGHTING SECOND FLOOR PLAN
2. *Drawing 9.0 (See sketch SK-E.1) –*
 - a. Added a panel schedule for panel A5 with new circuit breakers for the new hand dryers.

3. *Drawing 9.1 (See sketch SK-E.2) –*
 - a. New 2x2 light fixtures are to be Finelite / HPR-LED-A-2X2-DCO-S-840-120/277V-SC-C1 or approved equal.
4. *Drawing 9.2 (See sketch SK-E.3) –*
 - a. Added the demolition of the warm air hand dryers in the 2nd floor men's and women's toilet rooms.
 - b. Added note "ED-3" to the electrical demolition notes.
 - c. Removed demolition of thermostats from the electrical drawings (no revised drawing of sketch to reflect this change).
5. *Drawing 9.4 (See revised drawing E9.4) –*
 - a. Added the location of the existing panel A5.
 - b. Added hand dryers and circuits to 2nd floor men's and women's toilet rooms.
 - c. Added note "E-3" to the electrical notes.
6. *Drawing 9.5 (No revised drawing or sketch issued to reflect this change)–*
 - a. New 2x4 fluorescent light fixtures are to match existing 2x4 fixtures. Contractor to verify that the new fixtures visually match the existing fixtures prior to ordering.

Questions and Answers:

1. Are there any new sprinkler heads that need to be added? Are there any existing sprinkler heads that will be to be moved? If so, a drawing is needed.

Answer: The Building does not have a sprinkler system

2. Is there any room signage? if so locations and signage details are needed.

Answer: Add a \$5,000.00 signage Allowance in the lump sum amount, location will be determined during construction.

END