



ARCHITECTURE
ENGINEERING

Date: July 24, 2019

Re: **DTCC AUTOMOTIVE CENTER OF EXCELLENCE**
Georgetown, Delaware
2018242.00

ADDENDUM THREE

This addendum forms a part of the contract documents and modifies the original bidding documents dated July 2, 2019, and Addenda, as noted below.

PROJECT MANUAL

1. ADVERTISEMENT FOR BIDS
 - a. REVISE Bid Date from “August 1, 2019” to “**August 6, 2019.**”
2. INVITATION TO BID
 - a. REVISION: All RFI’s must be submitted to ehammond@beckermorgan.com no later than 2:00 PM local time on **July 26, 2019.**
3. INSTRUCTIONS TO BIDDERS
 - a. REVISION: Addenda will be issued no later than **July 31, 2019** except an addendum revising the bid date.
4. SECTION 083613 - SECTIONAL DOORS
 - a. Under 2.3A.1., ADD :c. Haas Door.”
 - b. Under 2.L1., DELETE “Baked-Enamel or.”
 - c. Under 2.5B., DELETE reference to “6-mm-thick, clear acrylic glazing.”
 - d. Under 3.2B, ADD “3. Install tracks as close to exposed ceiling as possible regardless of height of door openings.
 - e. CLARIFICATION: Fire-rated glazing is not required in sectional doors.
5. SECTION 088000-GLAZING
 - a. Under 3.10B1, REPLACE “Acid-etched” with “Frosted.”
6. SECTION 106301-PREFABRICATED HANGER ROD CANOPIES
 - a. Under 2.1, ADD “3. Metal Building Systems Manufacturer if equivalent.”
7. SECTION 236000-HEATING, VENTILATING, AND AIR CONDITIONING EQUIPMENT
 - a. Under 2.6.A.2. ADD Buderus as an acceptable manufacturer.

DRAWINGS

1. P101
 - a. REVISE Incoming Fire Protection Service from 6” to 8” per the attached drawing.
 - b. REVISE Note 4 Fire Protection Pipe from 6” to 8” per the attached drawing.



ARCHITECTURE
ENGINEERING

- c. ADD compressed air pipe to wheel alignment machine per the attached drawing.
 - d. ADD Note 8 to Drawing Notes per the attached drawing.
- 2. P102
 - a. REVISE Note 4 Fire Protection Pipe from 6" to 8" per the attached drawing.
- 3. P401
 - a. REVISE Backflow Preventer 2 Line Size from 6" to 8" per the attached drawing.
- 4. P503
 - a. ADD compressed air pipe to wheel alignment machine per the attached drawing.

Attachments: P101, dated 7/24/19
P102, dated 7/24/19
P401, dated 7/24/19
P503, dated 7/24/19