



**DELAWARE HEALTH  
AND SOCIAL SERVICES**  
Division of Management Services

*"DMS – Serving Those Who Serve Delaware"*

PROCUREMENT

**BID # 10-098-DENTALEQUI**

For

DENTAL EQUIPMENT

Required for Use By

Bureau of Oral Health and Dental Services

Date Due: **October 13, 2010, 11:00 AM EDT**

**ADDENDUM # 1**

Please Note: The attached sheets hereby become a part of the above mentioned bid.

Handwritten signature of Sylvia Adams in cursive script.

Sylvia Adams  
Purchasing Coordinator

Handwritten signature of William Ingram in cursive script.

William Ingram  
Contract Administrator

**Questions and Answers  
from Pre-bid Meeting  
HSS 10-098-DENTALEQUI  
September 23, 2010**

- 1) Is the provided floor plan current?

**Answer: YES.**

- 2) Upon inspection of physical site it is noted there is no drain for the staff area sink shown on the floor plan – will a sink still be installed in the location indicated on the floor plan?

**Answer: YES. The sink is to be installed in the location noted on the floor plan (Staff Room). The drain will be pump-based so no floor drain will be needed. Water supply will come from above.**

- 3) Can we get construction specs for plumbing and electrical?

**Answer: Electrical plans will be e-mailed to the bidders who attended the pre-bid meeting. Plumbing plans are unavailable.**

- 4) Is the electric supply 230 volt single phase?

**Answer: Electrical supply is 3-phase 208 volts flash 120 volts.**