

State of Delaware Department of Natural Resources and Environmental Control Delaware Division of Parks and Recreation 89 Kings Highway Dover, Delaware 19901

CONTRACT DOCUMENTS & TECHNICAL SPECIFICATIONS ADDENDUM NO. 2

CAPE HENLOPEN STATE PARK SANITARY SEWER REHABILITATON – SEWER LINING CONTRACT No. 2014-CH-100 May 2, 2014

This Addendum shall be attached to the specifications and/or drawings of the above named project and shall become part of the contract documents. All statements made herein shall supersede statements in the main body of the specifications and items shown on the drawings with which they are in conflict. Work and materials not specifically mentioned herein shall be as described in the main body of the specifications and as shown on the drawings. The bidder must acknowledge the receipt of this addendum on page AD-2 00300-5 of the Bid Form.

CHANGES AND/OR ADDITIONS TO THE CONTRACT DOCUMENTS

Change Specifications as follow:

Table of Contents

1. Delete Table of Contents (TC-1 and TC-2) and replace with revised Table of Contents. Bidders shall notice the addition of *Appendix E American Iron and Steel Provisions*.

Section 00300 - Bid Form

- 2. Delete Section 00300 Bid Form in its entirety and substitute the revised Section AD-2 00300 Bid Form attached to this addendum.
 - a. Bidders will notice item 21 'Allowances No. 1 Inspection Services' of the Bid Forms has been removed.
 - b. Bidders will notice item 18 for Alternate 1 'Grout' has been provided a unit price of \$450.00.
 - c. Bidders will notice the addition of several forms associated with Section 00650



Water Pollution Control Revolving Loan Fund Requirements. Each Bidder must fill out each form to its entirety. These forms include the following:

- Appendix A: DBE Rule Term and Condition (1 page)
- Disadvantaged Business Enterprise (DBE) Program, DBE Subcontractor
 Performance Form (2 pages)
- Disadvantaged Business Enterprise (DBE) Program, DBE Subcontractor
 Utilization Form (2 pages)
- Compliance Statement (1 page)
- Notice to Prospective Subcontractors of Requirements For Certifications of Non-Segregated Facilities (1 page)

Section 01010 – Summary of Work

 Delete Section 01010 – Summary of Work in its entirety and substitute the revised Section AD-2 01010 – Summary of Work attached to this addendum. Bidders will notice Section 1.2.4 for Inspection services has been removed.

Section 01020 – Allowances

2. Delete Section 01020 – Allowances in its entirety. There will be no longer be any allowances for this project.

Section 01025 – Measurement and Payment

3. Delete Section 01025 – Measurement and Payment in its entirety and substitute the revised Section AD-2 01025 – Measurement and Payment attached to this addendum. Bidders will notice *Bid Item 21 – Allowance No. 1 – Inspection Services* has been removed.

Section 02775 – Cured-In-Place Pipe Sectional Lining

4. Delete Section 02775 – Cured-In-Place Sectional Lining in its entirety and substitute the revised Section AD-2 02775 – Cured-In-Place Sectional Lining attached to this addendum. Bidders will notice *Item 3.3.a – Post-Construction Inspection of Completed Work* has revised language.

Response to Bidders Questions

Q1: Thank You very much for the opportunity to be approved as an "Our Equal" to the above referenced project and also becoming an approved process in upcoming projects for lateral lining. *Specification 00100 INSTRUCTIONS TO BIDDERS and Article 6 of Specification Section 01600 MATERIALS AND EQUIPMENT*. Please accept this e-mail as a written request for an approval as an "or equal". The product, in which we are presenting for approval is a proven lining system from Epros / Trelleborg.

A1: We have reviewed the Epros DrainMtH lateral lining system in accordance with *Specification 00100 INSTRUCTIONS TO BIDDERS* and *Article 6 of Specification Section 01600 MATERIALS AND EQUIPMENT* and approve this system as a substitution for use on this project provided hydrophilic sealant is applied during liner insertion in accordance with Specification Section 02750.3.03.A.

Q2: Is there an Engineer's estimate available for this project?

A2: The Engineer's estimate is not available.