



State of Delaware
Department of Natural Resources and Environmental Control
Delaware Division of Parks and Recreation
89 Kings Highway
Dover, Delaware 19901

ADDENDUM No. EIGHT

Project Name: Campground Improvements
Cape Henlopen State Park

Project No.: CH-44

Contract No.: 2015-CH-300

Date of Issue: August 5, 2015

Notice No. 1: Attach this addendum to the Project Manual for this project. It modifies and becomes part of the Bidding Documents. Work or material not specifically mentioned herein is to be as described in the main body of the specification and as shown on the drawings.

Bids Due: Wednesday, August 10, 2016 at 3:00 PM
Auditorium
DNREC, Division of Parks and Recreation
89 Kings Highway, Dover DE 19901

Questions with Responses:

- 1 Question: Plan details & specifications do not mention that a separate ground rod and ground wire be attached to the power posts. This was required by the electrical inspector on other jobs we have done with similar pedestals. We contacted the electrical inspector regarding this project and were told that this would be a requirement to pass the electrical inspection. Due to the quantity of power posts please clarify the bonding requirements at the power posts.
- Response: Each power post is to be grounded. Provide ¼-inch dia. X 10-foot long copper clad steel ground rod buried adjacent to each power post. Provide #4 BCSD ground wire to power center lug. Exothermic weld ground wire to grounding rod.

End Addendum Eight