

# STATE OF DELAWARE DEPARTMENT OF NATURAL RESOURCES & ENVIRONMENTAL CONTROL

#### **DIVISION OF FISH &WILDLIFE**

89 Kings Highway Dover, DE 19901

# CONTRACT DOCUMENTS & TECHNICAL SPECIFICATIONS ADDENDUM NO. 2

# DELAWARE BAYSHORE BYWAY COOPER-CROSS WILDLIFE VIEWING ENHANCHMENTS CONTRACT NO. FW-1-15

**Project Name:** Delaware Bayshore Byway

Cooper-Cross Wildlife Viewing Enhancements

Contract No.: FW-1-15

**Date of Issue:** November 7, 2017

**Notice No. 1:** Attach this addendum to the Project Manual for this project. It modifies

and becomes part of the Bidding Documents. Work or material not

specifically mentioned herein is to be as described in the main body of the

specifications and as shown on the drawings.

**Bids Due:** November 17, 2017, 2:00 PM EST

"CONTRACT NO. FW-1-15 - SEALED BID - DO NOT OPEN".

Dept. of Natural Resources & Environmental Control

Division of Fish and Wildlife

89 Kings Highway, Dover DE 19901

Attn: Anthony T. Gonzon Jr., Delaware Bayshore Initiative Coordinator

#### 1. **QUESTIONS**:

1. Will a soils report be provided?

**RESPONSE:** Boring reports were provided via ADDENDUM NO. 1.

2. What is the correct manufacturer number for the removable bollard?

**RESPONSE:** The correct number is BPD-YL-3 1/2-52-S

We Bring You Delaware's Great Outdoors through Science and Service

3. Can we use 0.125" or 0.25" wire mesh?

RESPONSE: Per Specifications Section T-057300, Part 2.2.F Woven-Wire Mesh: Intermediate-crimp, square pattern, 2" (50-mm) woven-wire mesh, made from 0.135-inch (3.5-mm) diameter wire complying with ASTM A510/A510M

## 2. DRAWINGS:

1. **Drawing ES-1 General Sequence of Construction Note 9:** The wildflower seed mix shall be manually seeded and include all of the following at 7 pounds per species per acre:

Asclepias incornata
Asclepias syriaca
Rudbeckia hirta
Heliopsis lelianthoides
Swamp Milkweed
Common Milkweed
Black eyed susan
Oxeye Sunflower

#### 3. **SPECIFICATIONS:**

None

### 4. <u>ADDITIONAL INFORMATION:</u>

None

#### ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

#### **IF YOU HAVE ANY QUESTIONS, PLEASE CONTACT:**

Anthony Gonzon (anthony.gonzon@state.de.us)

Attachments: None