

Contractor Questions

<i>Question #</i>	<i>Page Index</i>	<i>Contractor's Question</i>	<i>Engineer's Response</i>
1	C108	Can the Department specify the finish (plain, galvanized, epoxy coated, etc) for the sheetpile cap (Detail 1/C108)?	The sheet pile cap finish shall match the specifications for the steel sheet piles.
2	-	Are borings or geotechnical information provided?	No borings or geotechnical information is provided. Driving criteria for all piles is provided on the project plans.
3	-	Confirm that a 3rd party DE PE is required to witness all pile driving activities.	All pile driving records shall be compiled and attested to by a Delaware licensed PE. The PE does not need to be a third party individual.