



STATE OF DELAWARE  
New Castle County Vocational Technical School District

April 4, 2018

TO: ALL OFFERORS

FROM: Sean Sokolowski

SUBJECT: ADDENDUM TO REQUEST FOR PROPOSAL NO. 1:  
Renovations to the Howard High School of Technology – Bid Package 'N'

**ADDENDUM NO. 1**

**TO**

**NEW CASTLE COUNTY VOCATIONAL TECHNICAL SCHOOL DISTRICT  
HOWARD HIGH SCHOOL OF TECHNOLOGY  
BID PACKAGE 'N'  
WILMINGTON, DELAWARE**

NOTICE: Attach this Addendum to the Project Manual for this project. It modifies and becomes a part of the Contract Documents. Work or materials not specifically mentioned herein are to be as described in the main body of the Specifications and as shown on the Drawings.

Acknowledge receipt of the Addendum in the space provided on the Bid Form. This Addendum is being transmitted to all contractors who have received Contract Documents. If there are any problems with legibility or content, please contact ABHA Architects, Inc. (302) 658-6426.

**ATTACHMENTS**

IRRIGATION Specification Section 02 8400 – (7 pages)  
ORNAMENTAL FENCE & GATE Specification & Diagrams- (9 pages)

**BIDDERS QUESTIONS AND ANSWERS**

Clarifications/Questions Response

- Q1. How is the fence to be mounted in ground and in retaining wall.  
A1. Mount gate posts in ground. Mount fence posts in existing concrete retaining wall. New core drills for all posts. Post depths per manufacturer requirement.

#### REVISIONS TO PROJECT MANUAL

Section 02 8400 – Irrigation  
Insert new specification section.

Section - Ornamental Fence and Gate  
Insert new specification section

#### CLARIFICATION:

Contractor to furnish and install a commercial motorized swing gate opener at new fence gate.

Bid Pac N  
END OF ADDENDUM NO. 1

All other terms and conditions remain the same.