



**Gipe Associates, Inc.**  
CONSULTING ENGINEERS

W.O. #: 19003

**ADDENDUM NO. 4– October 3, 2019**

RE: **DELCASTLE HIGH SCHOOL CHILLER/COOLING TOWER  
REFURBISHMENT (CONTRACT NUMBER – 1907)**  
GAI # 19003

FROM: Gipe Associates, Inc.  
8719 Brooks Drive,  
Easton, MD 21601

TO: Prospective Bidders

This addendum forms a part of the contract documents and modifies the original bidding documents dated **August 5, 2019** as noted below. Acknowledge receipt of this Addendum on the Bid Form. Failure to do so may subject bidder to disqualification.

This Addendum consists of one(1) page and only includes the below clarifications/answers.

**CLARIFICATIONS:**

RFI #	Question	Answer
RFI #1	Verify that only the original bid form is required and no additional copies.	Correct. Only one copy of bid forms/documents need to be submitted.
RFI #2	Is duct liner required for duct connecting to EF-1 and if it is should it be double wall?	Per Spec Section 23 30 00 – HVAC Air Distribution, Article 2.7, Paragraph A – All low pressure ductwork within 10 feet of exhaust air fans shall be provided with sound lining. Paragraph B. All internal duct lining for low pressure duct systems shall be provided with an interior galvanized perforated liner.

**END OF ADDENDUM #4**



## Addendum Transmittal

Gipe Associates, Inc. - Easton | 8719 Brooks Drive Easton MD 21601 United States

PROJECT:	DelCastle High School - Chiller/Cooling Tower Refurbishment 19003.0	DATE SENT:	10/3/2019
SUBJECT:	Addendum #4	ADDENDUM ID:	004
TYPE:	Addendum	TRANSMITTAL ID:	00005
PURPOSE:	For Information Only	VIA:	Info Exchange

### FROM

NAME	COMPANY	EMAIL	PHONE
Adam Kegan	Gipe Associates, Inc. - Easton	AKegan@GIPE.NET	4108228688

### TO

NAME	COMPANY	EMAIL	PHONE
Chase Lockard	Modern Controls, Inc.	clockard@moderncontrols.com	3023256800
Danny Jones	Gaudelli Brothers	ruth@gaudellibros.com	856-825-0636
daniel@degli.com		daniel@degli.com	
Mike Menocheh	Denver-Elek Inc.	estimating@denver-elek.com	
Dan Eaton	Summit Mechanical	hayley@summitmechanical.org	302-836-8814
Joe Giordano	Flo Mechanical	joeg@flomechanical.com	302-766-2999
Steve Stelzer		stephen.f.stelzer@carrier.com	267-634-4879
Andrea DiFabio		andrea@gemmsi.com	610-361-9667
john.b.walker@jci.com		john.b.walker@jci.com	
kevin.r.kelly@jci.com		kevin.r.kelly@jci.com	
carl.rifino@cherokee-crc.com		carl.rifino@cherokee-crc.com	
Jose Wallbright		jose@ecph.net	302-266-0530
sean.sokolowski@nccvt.k12.de.us		sean.sokolowski@nccvt.k12.de.us	

### DESCRIPTION OF CONTENTS

QTY	DATED	TITLE	NUMBER	SCALE	SIZE	NOTES
1	10/2/2019	2019-10-03 Addendum #4 - Delcastle Chiller-Tower Project.pdf				

### COPIES:

David Hoffman  
Leah Schultz

(Gipe Associates, Inc. - Easton)  
(Gipe Associates, Inc. - Easton)

## Addendum Transmittal

DATE: 10/3/2019  
ID: 00005

Al Schrum  
Adam Kegan

(New Castle County Vocational Technical School District)  
(Gipe Associates, Inc. - Easton)