



# Gipe Associates, Inc.

CONSULTING ENGINEERS

W.O. #: 20009

## ADDENDUM NO. 1 – MAY 8, 2020

RE: **DELCASTLE HIGH SCHOOL WELDING LAB  
(CONTRACT NUMBER – 2005)  
GAI # 20009**

FROM: Gipe Associates, Inc.  
8719 Brooks Drive,  
Easton, MD 21601

TO: Prospective Bidders

This addendum forms a part of the contract documents and modifies the original bidding documents dated **APRIL 17, 2020** as noted below. Acknowledge receipt of this Addendum on the Bid Form. Failure to do so may subject bidder to disqualification.

This Addendum consists of one page.

### REQUEST FOR INFORMATION AND RESPONSE:

1. I don't see a detail of the roofing. Can a detail be provided?

**Response: Roof details beyond what is shown on drawing M3.2 for curbs and duct penetrations of roofing will not be provided. Detail of roofing shall be based on existing roof manufacturer/vendor requirements (Carlisle Roofing System Installed by P&C Roofing).**

2. Is the current roof under warranty? If so, who owns the warranty?

**Response: Yes. P&C Roofing**

3. Who is the basis of design for the welding exhaust fans?

**Response: Per Specification section 23 82 21, Article 2.1 Welding Exhaust Fans, Paragraph A, subparagraph g. the basis of design is a Greenheck Vektor Model-MH.**

Addendum #1 – Page #1

**END OF ADDENDUM**