



# NEW CASTLE COUNTY VOCATIONAL-TECHNICAL SCHOOL DISTRICT

---

1417 NEWPORT ROAD, WILMINGTON, DELAWARE 19804  
(302) 995-8050

YVETTE SANTIAGO  
President  
Board of Education

JOSEPH JONES, Ed.D.  
Superintendent

MADELINE BOLDEN JOHNSON  
Vice President  
Board of Education

## Bid 2006 – St Georges Fencing Questions and Answers

- Q1) Is there a specification for the vinyl coated wire in Alt #2?  
A1) Vinyl Coated Fence should be 2x9 ga
- Q2) When is the estimated Start Date for this project?  
A2) Work will commence as soon as possible after Board approval on June 22<sup>nd</sup>.
- Q3) Is there a specification for the driven posts in Alt #1?  
A3) Fence posts should be driving a minimum of 36 inches.
- Q4) Can bids be submitted though email?  
A4) No.