



315 S. Chapel St.
Newark, DE 19711
Phone
302.738.7172
Fax
302.738.7175
www.dedc-eng.com

PRE-BID MEETING SUMMARY
DELAWARE STATE POLICE FIRING RANGE
BOILER REPLACEMENT
OMB/DFM # MC1002000238
ADDENDUM #2

QUESTIONS:

1. Do we fill oil trench with concrete?

Answer: No, the contractor is not responsible to fill the oil piping trench with concrete.

2. Do we pour a pad for future boiler #3 under this contract?

Answer: Yes, a concrete pad will need to be poured for future boiler #3 under the base bid of this contract.

DRAWING CHANGES:

1. On drawing E-100, Detail 3/E-100, homerun circuits for BP/1 and BP/2 were changed from "PP2" to HVAC-19,21,23" and "HVAC-20,22,24", respectively. Refer to attached drawing E-100 for Revision #1 changes.

Summarized By: DEDC, LLC
David Barton
Date: 08/22/14

DRAWING REDACTED