



315 S. Chapel St.
Newark, DE 19711

Phone
302.738.7172

Fax
302.738.7175

www.dedc-eng.com

PRE-BID MEETING SUMMARY
DELAWARE STATE POLICE FIRING RANGE
BOILER REPLACEMENT
OMB/DFM # MC1002000238
ADDENDUM #3

DRAWING CHANGES:

1. On drawing MD-100, detail 3/MD-100, the demo note referring to the underground storage tank has been updated. (D) 1" existing fuel oil supply and return from underground storage tank to outside of building and cap. Demo of underground storage tank is being handled by others in a separate contract. Refer to attached drawing MD-100 for Revision #1 changes.

Summarized By: DEDC, LLC
David Barton
Date: 08/25/14

DRAWING REDACTED