

Addendum #5

Date: September 12, 2018

Project: Carvel State Office Building -
Lobby Renovations

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

Clarifications

1. It was brought to our attention there is a conflict in gauge to be used for the floor framing. Please use 20ga as specified in Addendum # and not what is shown on drawing A4.5.

END