

**Addendum
No. 3**

Addendum Date: April 9, 2018
Project: Electrical Panel Replacement Phase 2 at
The Carvel State Office Building
DFM Project No: MC1002000396

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

Bidder Questions / Responses:

1. **Question** – Are we responsible for the work in Summary section 01 10 00 general standards #31?
If so, none of this work is shown on the drawings.
Response – The line in question describes a general standard for duct smoke detector installations but the general standard is not applicable for this project as there are no new duct smoke detectors.

Changes to Specifications:

None.

Changes to Drawings:

None.

General Information:

None.

END