

*Michael R. Wigley, AIA, LEED®AP
Jason P. Loar, P.E.
W. Zachary Crouch, P.E.
Michael E. Wheedleton, AIA
Ring W. Lardner, P.E.*

DHSS HOLLOWAY CAMPUS

CARVEL BUILDING ELEVATOR UPGRADES

HOLLOWAY CAMPUS, NEW CASTLE, DELAWARE

DBF #0586B035.V01 □ OMB/DFM# MC3501000039

FEBRUARY 2, 2018

ADDENDUM NO. 4

The following items shall become a part of the contract documents. Contractor must acknowledge receipt of this addendum on the Bid Form. Failure to do so may subject the Bidder to disqualification.

- Item No. 1 Refer to Specification Section 14 24 00 HYDRAULIC ELEVATORS
Revise all references to the 2010 ASME A17.1 Elevator Safety Code to read “2013 ASME A17.1 Elevator Safety Code.”
- Item No. 2 Refer to Drawing Sheet T2, CODE DATA
In Item 1. APPLICABLE CODES, after “ASME A17.1/ CSA B44”, delete “2012” and replace with the following:
ASME A17.1-2013 and ASME A18.1-2008 as currently adopted in the 2015 International Building Code, as amended by New Castle County and the New Castle County Property Maintenance Code.
- Item No. 3 Below is a question received and the Engineer’s response (*in italic*):
- A. On drawing E1 Lower Level Floor Plan-New Work, there is a note stating to hook up a sprinkler valve to the existing FACP. It refers to drawing FP-1 for a location of the Fire Alarm Panel. However I do not see the location of this panel on FP-1. Can you clarify the location of the existing FACP?
- Reply:
The note on Drawing E-1 refers to the location of the sprinkler valve, not the Fire Alarm Control Panel; however, the FACP is located in the building Main Lobby.

END OF ADDENDUM