



315 S. Chapel St.
Newark, DE 19711
Phone
302.738.7172
Fax
302.738.7175
www.dedc-eng.com

102 WAPLES WAY HVAC RENOVATION
OMB/DFM CONTRACT #'S MC3511000007
ADDENDUM #4

CLARIFICATIONS:

1. Item #1 from Addendum #3 stating that Control Technologies, Inc. is approved as a 3rd ATC vendor was issued in error. The two controls contractors listed in the specification are the only acceptable ATC vendors on this project.
2. Due to the late distribution of this 4th Addendum, the due date for bids is extended to Wednesday, October 24th at 9:30am and the bid opening will occur at that time, at the same location previously scheduled.
3. On drawing M-104 the following items shall be revised as follows
 - a. In the sequence of operation the first paragraph shall be deleted in its entirety and replaced with the following:

THE SYSTEM CONSISTS OF A PACKAGED ROOFTOP UNIT WITH A FILTER SECTION, GAS FIRED FURNACE REHEAT SECTION, DX COOLING SYSTEM AND A SUPPLY AIR FAN.

Addendum #4 Summary

- A. Summary (this document) – 1 pages

Summarized By: Delaware Engineering and Design Corporation
Daniel Fitzpatrick, P.E.
Date: Thursday, October 18th, 2012