



315 S. Chapel St.  
Newark, DE 19711  
Phone  
302.738.7172  
Fax  
302.738.7175  
[www.dedc-eng.com](http://www.dedc-eng.com)

101 LLOYD LANE HVAC RENOVATION  
OMB/DFM CONTRACT #'S MC351100008  
ADDENDUM #4

CLARIFICATIONS:

1. Item #1 from Addendum #3 stating that Control Technologies, Inc. is approved as a 3<sup>rd</sup> ATC vendor was issued in error. The two controls contractors listed in the specification are the only acceptable ATC vendors on this project.
2. Due to the late distribution of this 4<sup>th</sup> Addendum, the due date for bids is extended to Wednesday, October 24<sup>th</sup> at 9:00am and the bid opening will occur at that time, at the same location previously scheduled.
3. On drawing M-104 the following items shall be revised as follows
  - a. In the Rooftop AHU schedule, the model # for AHU-1, AHU-3 & AHU-5 shall be J05ZFN08D2BZZ2001 instead of J05ZRN08D2BZZ2001 as shown. The model # for AHU-2 & AHU-4 shall be J04ZFN06P2BZZ2004 instead of J04ZRN06P2BZZ2004 as shown.
  - b. In the sequence of operation the first paragraph shall be deleted in its entirety and replaced with the following:

*THE SYSTEM CONSISTS OF A PACKAGED ROOFTOP UNIT WITH A FILTER SECTION, GAS FIRED FURNACE REHEAT SECTION, DX COOLING SYSTEM AND A SUPPLY AIR FAN.*

Addendum #4 Summary

- A. Summary (this document) – 1 pages

Summarized By: Delaware Engineering and Design Corporation  
Daniel Fitzpatrick, P.E.  
Date: Thursday, October 18<sup>th</sup>, 2012