

November 17, 2014

To: All Contractors

From: Professional Roof Services (*ejem*)

Re: Addendum #3
101 Boyd Boulevard & 102 Lloyd Lane Buildings
Roof Replacement Projects
Contract No. MC3511000020 & MC3511000022

1. Both ¼ inch and ½ inch thicknesses of the Securock coverboard are called for in the specifications for these jobs. The correct thickness of the Securock coverboard is ½". Please make sure your bid proposals reflect pricing for correct thickness of the Gypsum-Fiber Roof Board.
2. Separate contract numbers have been assigned to both of these jobs and each will require separate Performance and Payment Bonds.
3. Bids are due on Wednesday, November 19, 2014 at 1:30 P.M. Location is the State of Delaware, Office of Management and Budget, Division of Facilities Management, at the Thomas Collins Building, 540 S. DuPont Highway, Suite 1 (Third Floor), Dover, DE 19901.

End of Addendum

Cc: Terri McCall, State of DE - OMB
Don Hickman, State of DE - OMB
John Fox, State of DE – OMB
Stephen King, State of DE – OMB
Mike Sanders, Harvard Environmental
Connie Weiss, C.A. Weiss Associates
Brad Smith, PRSI
Blaine Chipola, PRSI
Mike McGonigle, PRSI
File