

November 18, 2014

To: All Contractors

From: Professional Roof Services (*ejemc*)

Re: Addendum #4  
101 Boyd Boulevard & 102 Lloyd Lane Buildings  
Roof Replacement Projects  
Contract No. MC3511000020 & MC3511000022

1. A question was asked about the thickness of the insulation for Alternate # 1. The Polyguard representative has advised that the typical thickness of insulation to be used when insulating ductwork would be 2.0 inches of fiberglass insulation.

**\*\*For informational purposes only.\*\***

End of Addendum

Cc: Terri McCall, State of DE - OMB  
Don Hickman, State of DE - OMB  
John Fox, State of DE – OMB  
Stephen King, State of DE – OMB  
Mike Sanders, Harvard Environmental  
Connie Weiss, C.A. Weiss Associates  
Brad Smith, PRSI  
Blaine Chipola, PRSI  
Mike McGonigle, PRSI  
File