

**ADDENDUM NO. 3  
CAMPBELL COTTAGE #C3 & C5  
GAS CONVERSION AT THE STOCKLEY CENTER  
OMB/DFM CONTRACT NO. MC3511000029  
DATE OF ISSUE: July 22, 2016**

- 1.0 This Addendum, Addendum No. 3, shall be made part of the Project Manual and Drawings dated July 4, 2016 for the Campbell Cottage #C3 & #C5 Gas Conversion at the Stockley Center. Bid Date and time remain unchanged 2:00 p.m. local time on Thursday, July 28, 2016,
- 2.0 Any provision in any of the Contract Documents which may be in conflict or be inconsistent with the contents of this Addendum shall be void to the extent of such conflicts or inconsistency.
- 3.0 Changes to Specifications  
3.1 There are no changes to the Specifications.
- 4.0 Changes to Drawings:  
4.1 There are no changes to the Drawings.
- 5.0 Questions/Clarifications  
5.1 The current drop ceiling follows the roof pitch in various areas. Is the intention that all new specified ceiling grid be hung level at an 8' +/- height?
- Reply:  
Yes, refer to General Notes 1 -4 on Drawings A-3 & A-7.

**End of Addendum #3**

EF/ef  
15-1179 Addendum #3 7.22.16

CC: All Registered Plan Holders