



240 Continental Drive, Suite 200
Newark, DE 19713
Tel: 302-738-7551
Fax: 302-454-5989

Addendum No. 2

Delaware Heath & Social Services
MAC Hot Water Conversion
Stockley Center
OMB/DFM/DHSS Contract No: MC3501000034

Tt Project No. 200-26912-16015

Addendum No. 2
To
Drawings and Project Manual

November 22, 2017

To: ALL BIDDERS

This ADDENDUM forms a part of the BIDDING AND CONTRACT DOCUMENTS and modifies the following documents:

Original DRAWINGS dated November 7, 2017 and
PROJECT MANUAL dated November 7, 2017

Acknowledge receipt of the ADDENDUM in the space provided on the FORM OF PROPOSAL

This ADDENDUM consists of two (2) pages and the following:

2.1 **The Pre-Bid Meeting Minutes issued on 11/9/17 will be considered Addendum No. 1.**

2.2 **CHANGES TO THE PROJECT MANUAL**

A. None

2.3 **CHANGES TO THE DRAWINGS**

A. Sheet E-401. Partial Floor Plan Filter & Storage Room – New Work

1. In front of Boiler B-1 is Pump P-1. Pump shall be wired to Panel PP-2, Circuit #5 in lieu of the EF-1 currently identified in this circuit. EF-1 does not exist. Relabel breaker as “PP-1”. Refer to M-402 for Pump P-1 location and identification.
2. The pump located in the middle of the room is Pump P-2. The Circuit between the combo starter and existing pump (not labeled) is existing and shall be changed to light. Refer to M-402 for Pump P-2 location and identification.

2.4 **CLARIFICATIONS/REQUEST FOR INFORMATION (RFI'S)**

A. Cherokee Nation Mechanical, LLC. e-mail dated November 20, 2017

Question 1: According to the Panel Schedule on Drawing E-601 for Panel MDP, we are to provide a new breaker and service for Panel PP2. What is the location of Panel MDP relative to the location of the new Panel PP2? Can you provide a scaled drawing showing the location of each (on the same drawing)?

Response 1: Existing Panels MDP and PP-1 are located in the Filter Room's Northeast Corner (top right).

Question 2: What is the make and model of existing Panel MDP?

Response 2: This information is identified on the Panel Schedule.

END OF ADDENDUM 02

Attachments:

None.