



Pennsylvania
Duane Morris Plaza
30 S. 17th Street
Suite 830
Philadelphia, PA 19103
Phone
267.804.7286

Delaware
315 S. Chapel Street
Newark, DE 19711
Phone
302.738.7172
Fax
302.738.7175
www.dedc-eng.com

NORTHEAST TREATMENT CENTER
BATHROOM RENOVATIONS
OMB/DFM# MC3512000019
ADDENDUM #3

CLARIFICATIONS / RFI QUESTIONS:

1. Question #1: Does the nurse call system need to report to PC with software and licensing?

Response: No, the nurse call system specified does not require a PC with software and licensing. The individual call stations report back to the Nurse Call Annunciator Panel.

2. Question #2: For the nurse call system is plenum wire acceptable or does it all need to be in conduit?

Response: Plenum wire will be acceptable for the nurse call system.

Summarized By: DEDC, LLC
David Barton
Date: March 30, 2020