



315 S. Chapel St.  
Newark, DE 19711  
Phone  
302.738.7172  
Fax  
302.738.7175  
[www.dedc-eng.com](http://www.dedc-eng.com)

EMILY P. BISSELL HOPITAL  
NURSE CALL / WANDER GUARD SYSTEM REPLACEMENT  
OMB/DFM # MC3514000010  
ADDENDUM #2

QUESTIONS AND CLARIFICATIONS:

1. *How many tags for the wander system?*

Answer: 15 tags for residents will be required under the base bid.

2. *How many new cards for the access control system?*

Answer: No access control cards will be required with the new system.

3. *Will we be required to reprogram all existing cards into the new systems?*

Answer: Yes, you will need to reprogram all of the existing cards for the new systems.

4. *Reference: All Systems. Confirm that all system cabling can be run free air above ceiling and within wall cavities.*

Answer: All cabling above ceiling shall be hung from bridle rings as required.

5. *Reference: All Systems. Confirm that all system cabling must be plenum-jacketed.*

Answer: Yes, all system cabling must be plenum jacketed.

6. *Reference: All Systems. Confirm type(s) of acceptable below-ceiling surface raceway and back-boxes.*

Answer: Wiremold 500/700 Series small raceway (or equivalent) will be permitted only in areas where there is block wall. Most of the building is drywall and wiring can be fished through the wall. Refer to spec section 26 05 37 for boxes.

7. *Reference Section 27 52-13, Wander Prevention System. State quantity and type of Wander Tags to be provided.*

Answer: 15 patient wander tag bracelets are required under the base bid. Type of tags should be non-pulsating wrist tags.

8. *Reference: Sub-Contractor Qualifications. Is a Delaware Business License as well as a Delaware Electrical License required for the installation of all systems?*

Answer: Yes, you must have a Delaware business license and have a Delaware electrical license for installation of all systems.



315 S. Chapel St.  
Newark, DE 19711  
Phone  
302.738.7172  
Fax  
302.738.7175  
[www.dedc-eng.com](http://www.dedc-eng.com)

9. *Reference: Prevailing Wage Rates. Is the entire installation classified as “Electrical”, for prevailing wage consideration?*

Answer: Yes, the entire installation will be classified under the Electrical prevailing wage for New Castle County. Contact the Department of Labor for the determination of any other work required by this project.

10. *Does the wander guard system field wiring need to be installed in a raceway?*

Answer: Wiremold 500/700 Series small raceway (or equivalent) will be permitted only in areas where there is block wall. Most of the building is drywall and wiring can be fished through the wall.

11. *Does the Nurse call system field wiring need to be installed in a raceway?*

Answer: Wiremold 500/700 Series small raceway (or equivalent) will be permitted only in areas where there is block wall. Most of the building is drywall and wiring can be fished through the wall.

12. *Do we need to install our wire in conduit if we are above the ceiling or in a wall?*

Answer: All cabling above ceiling shall be hung from bridle rings as required.

#### SYSTEM SUBSTITUTION REQUESTS:

1. Nurse Call: The Telecor Nurse Courier 3 Communication System has been proposed as an approved equal to the Cornell 7000 Series Audio Nurse Call System. The Telecor Nurse Courier 3 Communication System has been reviewed and accepted as an approved equal.
2. Wander Guard: The Accutech Resident Guard LS 2400 wander guard system has been proposed as an approved equal to the Stanley RoamAlert wandering system. The Accutech system has been reviewed and not accepted as an approved equal.

Summarized By: DEDC, LLC  
David Barton  
Date: 10/08/14