

*Michael R. Wigley, AIA, LEED®AP
Randy B. Duplechain, P.E.
Charles R. Woodward, Jr., LS
W. Zachary Crouch, P.E.
Michael E. Wheedleton, AIA
Jason P. Loar, P.E.
Ring W. Lardner, P.E.
Gerald G. Friedel, P.E.*

**DELAWARE HOSPITAL FOR THE CHRONICALLY ILL
CANDEE BUILDING 100 WING
NURSES STATION RENOVATIONS
SMYRNA, DELAWARE 19977
OMB/DFM #MC3514000020
DBF #586B035.H01**

ADDENDUM NO. 1

The following items shall become a part of the contract documents. Contractor must acknowledge receipt of this addendum on the Bid Form. Failure to do so may subject the Bidder to disqualification.

- Item No. 1 Refer to specification section 08 88 53, SECURITY GLAZING, for glazing specifications.
- Item No. 2 As shown and noted on the interior elevations, each panel will have a speak hole. Each speak hole shall be 4" diameter.
- Item No. 3 The installation of the epoxy flooring shall be phased. The GC shall assume (2) two pours.

END OF ADDENDUM