

**Addendum
No. 2**

Date: November 27, 2017
Project: Governor Bacon Health Center
Tilton South-1 Nurses Station
MC3514000039

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

General

1. Is the E.C responsible for the cabling and terminations needed for all new telecommunication outlets?

No. Telecomm cabling and terminations will be provided by others.
Contractor shall provide boxes, conduit and pull string.

2. Provide room signage specifications.

Cosco Industries ADA Series 2, or architect approved equivalent.

6" x 6" x 1/8" thick

1 1/2" high room number

3/4" high room name

Square edge, radius corner, wall
mount, tape adhesive.

Helvetica, Arial or other sans serif
font, upper case only.

Colors: White lettering on blue
background to match existing.

Signs are required to comply with
ADA Standards and ICC A117.1 and
applicable building codes.



3. Should Sheet 3.1 Project Notes, Schedule of Alternate No. 1 should be corrected to read Alternate No. 2 instead?

No. Schedule of Alternates on drawings matches Schedule of Alternates in the Spec Book.

End