

*Michael R. Wigley, AIA, LEED®AP  
W. Zachary Crouch, P.E.  
Michael E. Wheedleton, AIA  
Jason P. Loar, P.E.  
Ring W. Lardner, P.E.*

**MEDICAL BUILDING WINDOW REPLACEMENT  
AT  
DELAWARE HOSPITAL FOR THE CHRONICALLY ILL  
SMYRNA, DELAWARE 19977  
DBF #586B035.G02 ❖ DFM # MC3514000041**

**FEBRUARY 27, 2018**

**ADDENDUM NO. 2**

The following items shall become a part of the contract documents. Contractor must acknowledge receipt of this addendum on the Bid Form. Failure to do so may subject the Bidder to disqualification.

- Item No. 1      Windows are not required to meet egress.
- Item No. 2      Clarification: Glass is not required to be laminated. The glass shall be insulated, low-E with Argon.
- Item No. 3      The performance class of the windows is CW; Performance Class LC is not acceptable.
- Item No. 4      Clarification: The GC is not permitted to share lift equipment with the abatement contractor. The abatement contract is separate from the GC contract.

**END OF ADDENDUM**