



240 Continental Drive, Suite 200  
Newark, Delaware 19713  
Tel. (302) 738-7551  
Fax (302) 454-5989/5988

## **Addendum**

---

### **JAMES T. VAUGHN CORRECTIONAL CENTER 'D' BUILDING SHOWER IMPROVEMENTS**

OMB/DFM/DOC Contract No.: MC3804000024  
Tt Project No. 26912-15005

#### **Addendum No. 3**

October 6, 2015

---

To: ALL BIDDERS

This ADDENDUM forms a part of the BIDDING AND CONTRACT DOCUMENTS and modifies the following documents:  
Original DRAWINGS and PROJECT MANUAL dated Sept. 15, 2015

Acknowledge receipt of the ADDENDUM in the space provided on the FORM OF PROPOSAL

This ADDENDUM consists of three (3) pages, including the attachments:

---

#### **1.0 GENERAL:**

- 1.1 Bid due Date – Unchanged from Advertisement – 2:00pm Thursday, October 8, 2015
- 1.2 Deadline for Questions – Close of Business Friday, October 1, 2015
- 1.3 Documents can be obtained / purchased at the office of Tetra Tech in Newark

#### **2.0 CHANGES to the PROJECT MANUAL - NA**

#### **3.0 CHANGES to the DRAWINGS : See RFI's below.**

#### **4.0 RFI's**

- 4.1 Q – (The) Drawings do not indicate where duct security bars are to be located? I'm assuming at all exhaust fan roof penetrations. What about all the new vertical duct on the first floor?  
A – The ductwork Security Sleeves (shown on M-105) shall be located at all penetrations, greater than 6" thru the precast concrete roof deck. This will include the vertical exhaust duct that extends up from the shower room chase.

#### **ATTACHMENT LIST – Sketch – C-SK-1\_ 10/5/15**

cc: All plan holders, E. Kulhanek

**END OF ADDENDUM No. 3**

